

# Wisconsin Case Studies: Using Rare Earth Chloride to Reduce Phosphorus to Ultra-Low Limits

**By:** Joseph Carlston  
Product Development Scientist

**Date:** 24 June 2015



- **Rare Earth Technology Introduction**
  - What are rare earths?
  - Rare earths vs. traditional P removal
- **Preliminary Lab Studies**
- **Plant Trials**
  - Equipment Set-up
  - Facility processes
  - Trial results
- **Conclusions / Summary**

- Rare earth elements are located in the lanthanide series (plus Sc and Y) of the periodic table
- Most prominently known for high strength, permanent magnets
- Unique reactivity with oxyanions, such as phosphate

|          |          |          |          |          |          |          |          |          |           |           |           |            |            |            |            |            |            |
|----------|----------|----------|----------|----------|----------|----------|----------|----------|-----------|-----------|-----------|------------|------------|------------|------------|------------|------------|
| 1<br>H   |          |          |          |          |          |          |          |          |           |           |           |            |            |            |            |            | 2<br>He    |
| 3<br>Li  | 4<br>Be  |          |          |          |          |          |          |          |           |           |           | 5<br>B     | 6<br>C     | 7<br>N     | 8<br>O     | 9<br>F     | 10<br>Ne   |
| 11<br>Na | 12<br>Mg |          |          |          |          |          |          |          |           |           |           | 13<br>Al   | 14<br>Si   | 15<br>P    | 16<br>S    | 17<br>Cl   | 18<br>Ar   |
| 19<br>K  | 20<br>Ca | 21<br>Sc | 22<br>Ti | 23<br>V  | 24<br>Cr | 25<br>Mn | 26<br>Fe | 27<br>Co | 28<br>Ni  | 29<br>Cu  | 30<br>Zn  | 31<br>Ga   | 32<br>Ge   | 33<br>As   | 34<br>Se   | 35<br>Br   | 36<br>Kr   |
| 37<br>Rb | 38<br>Sr | 39<br>Y  | 40<br>Zr | 41<br>Nb | 42<br>Mo | 43<br>Tc | 44<br>Ru | 45<br>Rh | 46<br>Pd  | 47<br>Ag  | 48<br>Cd  | 49<br>In   | 50<br>Sn   | 51<br>Sb   | 52<br>Te   | 53<br>I    | 54<br>Xe   |
| 55<br>Cs | 56<br>Ba | *<br>Lu  | *<br>Hf  | *<br>Ta  | *<br>W   | *<br>Re  | *<br>Os  | *<br>Ir  | *<br>Pt   | *<br>Au   | *<br>Hg   | 81<br>Tl   | 82<br>Pb   | 83<br>Bi   | 84<br>Po   | 85<br>At   | 86<br>Rn   |
| 87<br>Fr | 88<br>Ra | **<br>Lr | **<br>Rf | **<br>Db | **<br>Sg | **<br>Bh | **<br>Hs | **<br>Mt | **<br>Uun | **<br>Uuu | **<br>Uub | 113<br>Uut | 114<br>Uuq | 115<br>Uup | 116<br>Uuh | 117<br>Uus | 118<br>Uuo |
|          |          | *<br>La  | *<br>Ce  | *<br>Pr  | *<br>Nd  | *<br>Pm  | *<br>Sm  | *<br>Eu  | *<br>Gd   | *<br>Tb   | *<br>Dy   | *<br>Ho    | *<br>Er    | *<br>Tm    | *<br>Yb    |            |            |
|          |          | *<br>Ac  | *<br>Th  | *<br>Pa  | *<br>U   | *<br>Np  | *<br>Pu  | *<br>Am  | *<br>Cm   | *<br>Bk   | *<br>Cf   | *<br>Es    | *<br>Fm    | *<br>Md    | *<br>No    |            |            |



## Chemicals & Oxides

- ✓ Automotive (catalysts)
  - ✓ Ceramics
- ✓ Chemical catalysts
- ✓ Consumer electronics
  - ✓ Glass polishing
- ✓ Internal sales of magnetic materials
  - ✓ NiMH Batteries
- ✓ Petroleum refining
- ✓ Phosphors / Displays / Energy Efficient Lighting
  - ✓ Pigments
- ✓ Wastewater Treatment


## Magnetic Materials

- ✓ Automotive
- ✓ Computing / Networking
- ✓ Consumer electronics
  - ✓ Home Appliances
  - ✓ HVAC systems
- ✓ Industrial Automation
  - ✓ Office Automation
- ✓ Renewable Energy Systems
- ✓ Telecommunications

## Rare Metals

- ✓ Aerospace
  - ✓ Catalysts
- ✓ Electronics
  - ✓ LED Lighting
- ✓ Lithium Batteries
- ✓ Phosphors / Displays
  - ✓ Solar Power Cells
  - ✓ Super Alloys
- ✓ Superconductivity platforms
  - ✓ Wireless Communications





Traditional Markets

Emerging Markets



Glass Polishing



Hybrid Vehicle Batteries



Recreation Water



Catalytic Converters




Advanced Optics



Wastewater






- Precipitate is  $\text{CePO}_4$  (Rhabdophane)
- Forms ionic bonds
- Preferentially reacts with phosphorus
- Achieves a 1:1 molar ratio of  $\text{Ce}:\text{PO}_4$


- Forms  $\text{Fe}/\text{AlOOH}$  and  $\text{Fe}/\text{Al}(\text{OH})_3$  intermediates to adsorb P
- Phosphate adsorbs on the surface of the floc (surface chemistry)



- Rare earth chloride solution
- Active Ingredient: Cerium Chloride ( $\text{CeCl}_3$ )
  - Concentration: 31.5%
- Density: 12.4 lbs/gal
- Freezing Point  $-40^\circ\text{C}$
- pH: 3.5
  - Non-hazardous rating
- Compatible with existing equipment




**Molar Ratios of Coagulants Versus Final Concentration P**  
2.5 mg/L PO<sub>4</sub>-P Starting Concentration






**Molar Ratios of Coagulants Versus Final Concentration P**  
**1 mg/L PO<sub>4</sub>-P Starting Concentration**



### Coagulant Required to Reduce P to 0.1 mg/L



| <b>Temperature<br/>(°C)</b> | <b>Molar Ratio<br/>REE:P</b> | <b>RECl<sub>3</sub> Dosage<br/>(ppm<sub>v</sub>)</b> |
|-----------------------------|------------------------------|--|
| 5                           | 0.83                         | 7  |
| 20                          | 0.80                         | 7  |
| 40                          | 0.85                         | 7  |



- Sample tested: Secondary clarifier effluent
- Phosphorus Level: Spiked to 2 mg/L PO<sub>4</sub>-P using NaH<sub>2</sub>PO<sub>4</sub>
- Treated with CeCl<sub>3</sub> at volumetric dose rate of 50 ppm<sub>v</sub>
- Filtered and unfiltered samples submitted for acute whole effluent toxicity testing

|                              | <b>Water Flea</b> |            | <b>Fathead Minnow</b> |            |
|------------------------------|-------------------|------------|-----------------------|------------|
|                              | Filtered          | Unfiltered | Filtered              | Unfiltered |
| <b>NOEC Value</b>            | 100               | 100        | 100                   | 100        |
| <b>LC<sub>50</sub> Value</b> | >100              | >100       | >100                  | >100       |
| <b>TU<sub>a</sub> Value</b>  | < 1.0             | < 1.0      | < 1.0                 | < 1.0      |



- Samples Tested:
  - Secondary clarifier effluent (spiked to 2 mg/L PO<sub>4</sub>-P)
  - Centrifuge centrate (117 mg/L PO<sub>4</sub>-P)
- Treated with CeCl<sub>3</sub> at dose rates of:
  - 50 ppm<sub>v</sub> for secondary clarifier effluent
  - 3,000 ppm<sub>v</sub> for centrifuge centrate
- Unfiltered samples submitted for extraction testing via CalWET procedures




| <b>Contaminants</b>   | <b>Secondary Clarifier Effluent</b> | <b>Centrifuge Centrate</b> |
|---|-------------------------------------|----------------------------|
| <b>Fluoride</b>   | 0.91 mg/L                           | 1.5 mg/L                   |
| <b>Inorganics:<br/>Sb, As, Ba, Be, Cd, Total<br/>Cr, Hex. Cr, Co, Cu, Pb,<br/>Hg, Mo, Ni, Se, Ag, Tl,<br/>V, Zn</b> | BDL                                 | BDL                        |
| <b>Pesticides</b>   | BDL                                 | BDL                        |
| <b>Polychlorinated<br/>Biphenyls</b>  | BDL                                 | BDL                        |
| <b>Herbicides</b>   | BDL                                 | BDL                        |
| <b>Volatiles</b>  | BDL                                 | BDL                        |
| <b>Bases/Neutrals/Acids<br/>(Semi-volatiles)</b>  | BDL                                 | BDL                        |






- 45 MGD municipal WWTP in Mid-Atlantic US
- Total phosphorus limit of 0.18 mg/L P
  - Target of 0.10 mg/L P
- Interested in seeking new coagulant with lower consumption rate, less chemical solids produced, and less staining of UV







- $\text{CeCl}_3$  maintained phosphorus below limit with dosage rate 3x less than  $\text{FeCl}_3$
- Ferric usage: 34 ppm<sub>v</sub> = molar ratio 3.4:1 Fe/P
- $\text{CeCl}_3$  usage: 11 ppm<sub>v</sub> = molar ratio 0.7:1 Ce/P




- 2 MGD municipal WWTF located in Wisconsin
- Total P limit of 1.0 mg/L
  - New limit of 0.075 mg/L being enacted
- Used ferrous chloride ( $\text{FeCl}_2$ ) for chemical P removal
- Was unable to meet new TP limits with iron coagulant






- CeCl<sub>3</sub> maintaining ave. effluent TP < 0.03 mg/L with dose rate of 120 GPD
- Historical ferrous usage required 125-250 and only reduced TP to ave. of 0.5 mg/L



- 6-8 MGD municipal WWTF located in Wisconsin
- Total P limit of 1.0 mg/L
  - Future permit as low as 0.04 mg/L TP
- Used aluminum sulfate ( $\text{Al}_2(\text{SO}_4)_3$ ) for chemical P removal
- Unable to meet new TP limits with alum



Mixed Liquor sample - settling



Initial


1 min

2 min

4 min


5 min

10 min



| Tag Name  | Description          | Number | Server    | Color | Units | Minimum | Maximum | IO Address            | Time Offset | Source Tag |
|---|----------------------|--------|-----------|-------|-------|---------|---------|-----------------------|-------------|------------|
| <input checked="" type="checkbox"/> AI_55_PH... | PLANT EFFLUENT OR... | 1      | WPCP-S... |       | PPM   | 0.00    | 4.00    | \\wpcpscada1\DASAB... | 0:00:00.000 |            |

Plant Effluent – from 3.6 mg/L-PO<sub>4</sub> to 0.6 mg/L-PO<sub>4</sub> in 48 hours




- Achieved average of 0.15 mg/L TP in effluent for month of December with average of 50 ppm<sub>v</sub> RECl<sub>3</sub> dose
- Maintained average effluent TP at 0.6 mg/L with 200 GPD of RECl<sub>3</sub> compared to historical dose of about 700 GPD total chemical dose





- Average final sludge total solids increased from 25% to 29%




## Observed Benefits of Rare Earth Technology

- ✓ Able to achieve very low TP discharge limits without capital equipment
- ✓ Reduced sludge volumes compared to competitive coagulants
- ✓ Faster coagulation and noticeable impact than competitive coagulants
- ✓ Less coagulant volume required to reach low phosphorus limits
- ✓ Improved water clarity due to good coagulation properties
- ✓ Will not stain or discolor facility structures or equipment
- ✓ Compatible with existing dosing and filtration equipment
- ✓ Rated non-hazardous for DOT regulations



- City of Hartford, WI WWTP - Dave Piquett
- City of Fond du Lac WPCP - Jeremy Cramer, Autumn Fisher & team
- Mulcahy Shaw Water
- Ruekert & Mielke, Inc. - Dave Arnott
- Strand Associates - Jane Carlson, Troy Larson





---

Questions?

Pam Cornish

[PCornish@molycorp.com](mailto:PCornish@molycorp.com)

734-216-2089

Joseph Carlston

[JCarlston@molycorp.com](mailto:JCarlston@molycorp.com)