Hamilton's Incredibly Shrinking Consent Ordered Project Do Court Decisions in Parallel Districts and Regions Affect Your Treatment Plant?

June 24, 2015

Peter Kube, ARCADIS





Imagine the result



## Hamilton,OH



- County Seat for Butler County
- 63,000 people
- Separate Sanitary Sewer System
- 32 MGD Water Reclamation Facility
- Not immune to economic duress that began in 2007
- Shrinking Wastewater flows: ADF: 9 MGD

Closing Paper Plant = 30% Lost Wastewater Annual Operating Revenue



### Consent Order

#### Modified Consent Order



- No overflows for
  - 10 year-4 hour storm event
- WRF shall Treat
  - 10 year-24 hour event
- Create System Evaluation and Capacity Assurance Plan (SECAP)



SECAP Plan: System Evaluation and Capacity Assurance Plan

#### Modified Consent Order


5



- Outlined projects to accomplish Consent Order compliance("How-to")
  - Became part of the Modified Consent Order
- Many Projects, Two <u>major</u> Projects
  - Increased conveyance (Additional Interceptor)
  - 2. Increase treatment at WRF

SECAP: "How-To" Plan






2. Increased Treatment at the Water Reclamation Facility

#### Modified **Consent Order**

7

- SECAP Recommended Biological HRT Biological Ballasted Flocculation
- City examined recommendation further via a
  - Preliminary Engineering Report



Discussed Preliminary Engineering Report with OEPA  Preliminary Engineer SECAP recommended Alternative (1)

While Keeping Constraints the same

Preliminary Engineer Alternative 2

Preliminary Engineer Alternative 3

Preliminary Engineering Report






Design Progressed on Alternative 3

- Increased Influent Pumping
- Improvements to aeration tanks
- Addition of third secondary clarifier



Court Decision Occurs Elsewhere

lowa League of Cities vs. EPA (8<sup>th</sup> Cir, No 11-3412)






Court Decision Occurs Elsewhere lowa League of Cities VS. EPA (8<sup>th</sup> Cir, No 11-3412)



IOWA Senator






Guidance Letter to **Question #2**: re: Blending




### Guidance Letter to Question #1






### Guidance Letter to Question #2





Court Decision Occurs Elsewhere lowa League of Cities VS. EPA (8<sup>th</sup> Cir, No 11-3412)



Court Decision Occurs Elsewhere lowa League of Cities VS. EPA (8<sup>th</sup> Cir, No 11-3412)

#### The Ruling

•The EPA had used these specific guidance letters as rules without adhering to the Administrative Procedure Act.

•The guidance letter rules were vacated.

•However, The Court added that the EPA's guidance letter

"applies effluent limitations to a facility's internal secondary treatment processes, rather than at the end of the pipe." This "clearly exceeds the EPA's statutory authority....."

The Result

Use of Mixing Zones reverted to previous regulations and blending can occur in some fashion




### Previous Rules on Blending

- Prior to 2003- No Set Policy from EPA
- In 2003 EPA proposed Blending would NOT be a "prohibited bypass"
- In 2005 Blending was prohibited
- In 2011 the League asked if High Rate Treatment Ballasted
   Flocculation qualified as treatment

- EPA's guidance letter said "NO"



### Guidance Letter to Question #2





City went back to the Ohio EPA

- If we meet the modified consent order goals...
- With a revised approach
- that leverages all plant facilities to their full potential.....Would that be acceptable?



## 1950's

# 1970's


1990's

What was done at the plant?

RCADIS




© ARCADIS



#### **Increased** Pumping to meet Consent Order

Flow to Plant (MGD) - Atlas 14 10-year 24-hour Event




Increased Aeration Treatment Capacity

- Dry Weather flows have shrunk from 20 MGD to 9 MGD= available capacity
- Plant recently changed from surface aerators to fine bubble diffusers

 This project installed step feed/contact stabilization for the aeration basins.








### Secondary Clarifier Improvements





Clarifier Overflow Rates Comparison 1000 gpd/sf		1 ft <sup>2</sup> Gal/ day 1200 gpd/sf
10 States Standard (12 ft Side Water OH, WWTP Depth, 1,050 gpd/sf SWD) design peak (Stress test 1,170 gpd/sf)	IN, WWTP • 1,140 gpd/sf design peak (Stress testing 1,340 gpd/sf) 48 MGD:	OH, WWTP
	2 clariflers (14ft SWD) @ 1200 gpc	<ul> <li>1,200 gpd/sf</li> <li>design peak</li> </ul>

#### **ARCADIS**





#### Conclusions

Do Court Decisions in Parallel Districts and Regions affect your plant? YES It's good to monitor such cases to immediately act

The City leveraged every opportunity to meet consent order goals while upholding rate payers interests

- Repurposed existing Equalization Pump Station
- Salvaged abandoned (Interceptor) and Forcemain
- Re-used and increased treatment capacity
- Kept looking for the best alternate to accomplish goals
  - Project shrank from \$29 Million to \$5 Million (excluding the interceptor)

And ARCADIS Helped.



#### Questions

Peter Kube, PE ARCADIS (513) 985-8039 Peter.Kube@arcadis-us.com





# Imagine the result