

While We Are At, Nutrients Too, in Clark County

Bill Meinert, PE, Vice President - O'Brien & Gere
Bill.Meinert@obg.com



#obgPresents



Agenda

- *Clark County, OH, Southwest Regional Wastewater Treatment Plant*

- Design Development
 - ▶ Requirement – Expansion, Upgrade
 - ▶ Goal – Nutrient Removal

- Retrofit Details
 - ▶ Nutrient Removal

- Initial Performance

- Questions



■ Regulatory Activity

- ▶ Mad River TMDL
- ▶ OEPA's Nutrient Reduction Strategy (Pending)
- ▶ Gulf of Mexico Hypoxia Program (Pending?)



■ New NPDES Permit (March 2015)

- ▶ Capacity Expansion: 2.0 MGD → 4.0 MGD Rating (Future Need)
- ▶ Monthly NH₃-N Limit Decrease: 2.5 mg/L → 1.7 mg/L
 - ▶ **Additional Future Limits ?**
 - ▶▶ Assess Nutrient Removal Options

NPDES Permit Requirements – 4.0 MGD

Parameter	Requirement / Limit		Frequency
Flow	Report (MGD)		Daily
Dissolved Oxygen	Minimum 5.7 mg/L		Daily
BOD₅	mg/L	lbs/day	Weekly
	12	401	
	8.0	267	Monthly
TSS	18	602	Weekly
	12	401	Monthly
Ammonia-N (NH₃-N)	3.2	107	Weekly
	1.7	57	Monthly
E.Coli	284 #/100 mL		Summer Weekly
	126 #/100mL		Summer Monthly
Phosphorus (as P)	Report		Monthly
TKN (as N)	Report		Quarterly
Nitrite Plus Nitrate (NO_x-N)	Report		Monthly

Influent, Effluent Parameters – Design v. Actual (Startup)

Stream	Parameter	Unit	New Data	Old Data for Comparison		
			July 2014- Sept 2014*	March 2013- May 2014	Jan 2010- April 2012**	Peaking Factor Analysis
Influent	pH	SU		7.90	7.95	
	TSS	mg/L	391	315	280	298
	CBOD ₅	mg/L	234	162	133	128
Effluent	Flow	MGD	1.3	1.5	1.6	4.0
	Water Temp	°C	20.3	14.3	15.2	
	DO	mg/L	8.5	9.1	9.0	
	Max pH	SU	8.2	8.0	8.0	
	Min pH	SU	7.5	7.9	7.9	
	TSS	mg/L	4.0	3.0	1.8	
	NH ₃	mg/L	0.57	0.26	0.22	
	CBOD ₅	mg/L	2.9	2.1	3.0	
	NOx	mg/L	12.9	15.4	10.9	
	TP	mg/L	3.3	2.6	2.7	
	TKN	mg/L		1.2	1.3	
Overflow Occurrence	No.		0	0	0	
<i>*Review of monthly averages only</i>						
<i>**These influent values were used in the Basis of Design Mass Balance and Modeling Evaluations</i>						



Phosphorus Removal by Biological Means

■ Fundamentals of Bio-P:

- ▶ Requires Anaerobic-Aerobic sequencing
- ▶ **DO & NO_x must be used up for Anaerobic conditions**
 - ▶▶ *NO_x in RAS/ Denitrified in Pre-Anoxic Zone*
- ▶ Need Readily biodegradable COD and VFAs during Anaerobic
- ▶ Need Sufficient Aeration during Aerobic

■ Poly-phosphate released in Anaerobic, stored during Aerobic

- ▶ Stored Phosphorus is removed with the WAS






Importance of Influent Ratios

- BOD/N
 - ▶ >4.0 generally suggests sufficient BOD for effluent TN < 10 mg/L
- TKN/ $\text{NH}_3\text{-N}$
 - ▶ Greater values indicate higher organic content
 - ▶ Potential for higher effluent dissolved organic nitrogen (EDON)
- BOD/P
 - ▶ > 30 indicates potential for effective Bio-P
 - ▶ < 20 indicates minimal removal with Bio-P
- rbCOD/P
 - ▶ Most rbCOD gets converted to acetate for EBPR
 - ▶ 1 mg P removal for 6–10 mg/L rbCOD


Process Modeling

- Calibrated existing plant for existing limits
- Modeling to evaluate conditions for Bio-P, BNR
 - ▶ <math><1\text{ mg/L TP}</math>, 10 mg/L TN




Process Modeling – Oxidation Ditch Mode

Existing Ditches in Parallel Model Results
Secondary Effluent Variables v. Flow (MGD)




Low HRT.
MLSS Limit?
DO Control?

Process Modeling – Oxidation Ditch Mode



Process Modeling – Plug Flow Mode


Plug Flow Activated Sludge Model Results
Secondary Effluent TSS, BOD, and NH₃-N (mg/L) v. Flow (MGD)



Use Swing.
DO Control?
Carbon?

Oxidation Ditch vs. Plug Flow Operation

- Aerobic suspended growth process
 - ▶ Oxidation ditch (to 3.2 MGD?) vs.
 - ▶ Plug-flow configuration (to 4 MGD, BNR)



Effect of design factor on steady state effluent ammonia levels in complete mix and plug flow suspended growth reactors.


Oxidation Ditch vs. Plug Flow Operation

- Other Benefits
 - ▶ Improved Process Control
 - › Dedicated Zones
 - › Independent Mixing & Aeration
 - ▶ BNR
 - › > Nitrification, TN & Bio-P
 - ▶ Lower Capital Cost
 - ▶ Lower O&M Cost
 - ▶ *Floodplain*






Other Benefits of Biological Nutrient Removal

- Anoxic Treatment Reduces BOD w/o Oxygen
 - ▶ Reduce Overall Required Oxygen
- Anoxic/Anaerobic Conditions can enhance settleability
 - ▶ Select organisms, control filaments
- Bio-P can enhance alpha factor (oxygen uptake)
- Chem-P can increase inactive biomass




Oxidation Ditch BNR Conversion


■ Converting oxidation ditches to plug flow reactors



Overview – Process Flow Diagram



Project Basis / Overview – 4.0 Expansion Site Plan



Capacity Expansion from 2 to 4 MGD (10 MGD Peak)

Influent Screw Pumps (Ex. To Remain)

- Existing Screw Pumps to Remain (7.3 MGD Capacity)
 - Update when Peak Flow reaches 80% of firm pumping capacity

Influent Screening (Refurbish/New)


- Existing Mechanical Screen (5 MGD) to Remain
 - Add Second Mechanical Screen (5 MGD)
 - Replace Bar Rack (New 10 MGD, for Redundancy)
- New Shaftless Screw Screenings Conveyor

Grit Removal (New)

- New Vortex Grit Concentrators (With Stacked Tray Design)

Retrofitted Headworks Layout – Plan


- Headworks Facility
 - ▶ Doubled Screening
 - ▶ New Grit Removal
 - ▶ Other upgrades




Biological Treatment Zone Volumes

Zone	Train 1 Vol (MG)	Train 2 Vol (MG)	Total Vol (MG)	Primary Process Purpose
Pre- Anoxic /Anaerobic	0.11	0.11	0.22	RAS Denitrification/ Phosphorus Release
Swing	0.13	0.15	0.28	(Depends on Operation)
Aerobic	0.26	0.31	0.57	Nitrification/ P Uptake
Swing	0.15	0.18	0.33	(Depends on Operation)
Aerobic	0.09	0.10	0.19	Nitrification/ P Uptake
Total	0.74	0.85	1.59	BOD/Nutrient Removal


Ortho-Phosphorus Profile – Aerobic Swing Zones – 1.57 MGD



Ortho-Phosphorus Profile – Anaerobic Swing 1 – 3 MGD



Ortho-Phosphorus Profile – Secondary Release




Converted-PC Equalization to Pre-Anoxic/Anaerobic Reactors

New Baffle Wall
(One Per Zone)

36" Influent Pipe
(From Flow Distribution Box)

Submersible Mixers
(Two per Zone)



Converted Bioreactors (Upper Level)


Blower Pad
(4 New PD Blowers)

36" Effluent Pipe
(To Splitter Box)

42" Influent Pipe
(From Pre-Anoxic/ Anaerobic)

Intermediate Pump Station
(3 New, 3 Ex.)

Aeration Flow
Meters



Reactor No. 1: Outer Ring
Reactor No. 2: Inner and Middle Rings

Converted Bioreactors (Lower Level)

36" Effluent Pipe
(To Splitter Box)

42" Influent Pipe
(From Pre-Anoxic/ Anaerobic)

Intermediate Pump Station
(3 New. 3 Ex.)


Submersible Mixers
(In Swing Zones)

Fine Bubble Diffuser
Aeration Grids
(Supply Piping Around Tank)


Reactor No. 1: Outer Ring
Reactor No. 2: Inner and Middle Rings

Blower Pad
(4 New PD Blowers)

Aeration Flow
Meters




Biological – Equipment Installation Photos




Bioreactor Process Control

▲ SAMPLING POINT

■ DO METER



Bioreactor Process Flow & Control



Capacity Expansion from 2 to 4 MGD (10 MGD Peak)

Coagulant Storage and Feed

- Provisional, for intermittent use to ensure permit compliance

UV Disinfection

- Replacing Chlorine System, Increase Capacity to 10 MGD
 - Safety Concerns (Chlorine Storage)

Post – Aeration

- Convert old Chlorine Contact Tank to New Post- Air Tank
 - New Blowers, increase rating to 10 MGD

Tertiary Filters –Decommissioned in Place

Coagulant Feed – Improves / Backs Up P Removal





- **Upgraded to Biological Phosphorus Removal**
 - ▶ Low temperatures or inadequate influent ratios may inhibit BioP
 - ▶ Swing Zones in aeration mode may inhibit BioP
- **Coagulant added to enhance/back up Bio-P**
- **Can also enhance settling, reduce effluent TSS**

- **Alternatives:** Alum, Ferric Chloride, PACl, Sodium Aluminate, etc.
 - ▶ Installed: 35% Ferric Solution

- **Control:**
 - ▶ PCS automatically starts pumps when a pre-set effluent TSS is measured
 - › By TSS Effluent Monitor
 - ▶ Feed rate is manually adjusted

EFFLUENT TREATMENT

Coagulant Addition, UV, Post-Aeration



Coagulant Addition – Equipment Installation Photo




UV Disinfection – Equipment Installation Photo



Liquid Treatment - Average Flows (1.5 MGD)


Average Flows: 1.5 MGD



Liquid Treatment – Sustained Storm (4 MGD, 3-5 Days)

Average Flows: 1.5 MGD

Sustained Storm: 4 MGD




Liquid Treatment – Sustained Storm, Maintain Treatment

Average Flows: 1.5 MGD

Sustained Storm: 4 MGD

Storm, NR Issues: 5 MGD




Future Treatment? – Growth to Capacity, Or Lower Limits

Average Flows: 1.5 MGD

Sustained Storm: 4 MGD

Storm, NR Issues: 5 MGD

Storm, NR Issues: 5 -10 MGD




Training Sessions and Tools (Example - RAS/WAS Calculator)

- Enter Info Into Beige Cells
- Suggests WAS flows to achieve desired MLSS
- RAS rate to maintain


ENTER VALUES INTO CELLS THAT ARE HIGHLIGHTED	
WAS Rate	
Pre Anoxic Tank Volume, MG	0.11 each
Train 1 (outer ring) Tank Volume, MG	0.63 each
Train 2 (inner ring) Tank Volume, MG	0.74 each
No. of Pre-Anoxic/Anaerobic Tanks online	1.00 of 2 total
Is Plug Flow Bioreactor Train 1 online?	1.00 1 for yes, 0 for no
Is Plug Flow Bioreactor Train 2 online?	0.00 1 for yes, 0 for no
Pre-Anoxic working vol, MG	0.11
Bioreactor working vol, MG	0.63
Tot. Online Tank Volume, MG	0.74
Influent Flow, MGD	1.45 Enter current average flow in MGD, 4 MGD is basis of design flow
Actual current MLSS, mg/L	3,349.00 Enter value based on most recent lab or online instrument analysis
Desired MLSS, mg/L	4,050.40 Design modeling average was 4,050.4 mg/L
MLSS to be removed, lbs	-4,328.76 Negative indicates target MLSS is higher than current MLSS
Extra MLSS to be pumped in addition to WAS, MG	-0.04
RAS/WAS TSS, mg/L	11,779.86 Enter value based on most recent lab or online instrument analysis
Solids Inventory in Reactors, lbs	20,668.69
Desired Solids Inventory	24,997.45
WAS to maintain Solids Inventory, lbs/day	3,279.17 Based on removing Influent TSS conc. to effluent target conc.
Calculated SRT at current solids inventory, days	6.30 Average in design modeling was 5.93 days
Calculated SRT at target solids inventory, days	7.62 Average in design modeling was 5.93 days
Desired WAS rate, MGD	0.03 Based on maintaining solids inventory
Desired average WAS rate, GPM	23.18 Based on maintaining solids inventory
SC Effluent Target TSS, mg/L	8.71 Design modeling average was 8.7
Hours spent wasting sludge, hrs/day	16.00
WAS flow rate while wasting, GPM	34.77 Flow needed just to maintain solids inventory at current level
If a change is being made to the MLSS enter the number of days to be spent changing it.	9.00
WAS flow to correct MLSS, GPM	29.67 for 16.0 hours a day for 9.0 days. then return to 34.77 GPM for 16.0 hours a day

RAS rate	
Clarifier Diameter, ft	60.00
No. of SCs in use	3.00
Total Clarifier Influent, MGD	2.18
Tot. SC area in use, ft^2	8,482.30
Surface loading rate @ desired MLSS, (lb/day)/SF	7.10
Surface loading rate @ actual MLSS, (lb/day)/SF	6.51
SVI, mL/g	100.00
RAS rate, based on SVI, % of inf	50.35
RAS rate, based on SVI, MGD	0.73
SC Influent Solids, lbs/day	40,479.91
RAS solids, lbs/day	37,200.74
RAS, MGD	0.38
BR influent TSS, mg/L	280.00
Desired BR MLSS, mg/L	4,050.40
Underflow SS, mg/L	11,779.86
Effluent TSS, mg/L	8.71
BR influent flow, MGD	1.45
SC Effluent Flow	1.42
WAS flow, MGD	0.03
Minimum RAS Flow at Target MLSS, MGD*	0.70700
Minimum recommended RAS Flow, calculated based on current MLSS*	0.53


Initial Operation – Performance




Initial Operation – Performance




Initial Operation – Performance




Initial Operation – Performance




Initial Operation – Performance



Initial Operation – Performance



Initial Operation – Performance



Expansion, Upgrade, and ready for Nutrients

- Nutrient Removal is more cost effective when influent BOD is managed
 - ▶ Deliver the sBOD to where it is best utilized
- DO control easier and better in Plug Flow mode
- When matched in proper ratios to N and P, BNR is very effective
- *BOD is “Free Carbon”, little or no aeration needed with Nutrient Removal*
- Recycle loads from solids treatment can influence performance
- Cost-Effective Expansion & Upgrade
 - ▶ \$7.1M Project Cost
 - › Optimize existing infrastructure, \$2-3/GPD capital cost
 - › BNR (TN 10, TN 1) (*\$100-500k of \$7.1M?*)

QUESTIONS?

Bill Meinert, O'Brien & Gere

(443) 474-7332, Bill.Meinert@obg.com



#obgPresents



Thank you!



#obgPresents

