# What Goes Around Comes Around

How Ohio EPA Uses
What You Report



# 1972 Clean Water Act: Objective

To restore and maintain the chemical, physical, and biological integrity of the Nation's waters

"fishable/swimmable" goals



### **Important CWA Principles**

1. Discharge of pollutants is not a right

2. Point sources may not discharge pollutants to surface waters without a permit (e.g. NPDES permit)



# **Important CWA Principles**

- 3. Point sources must employ best available technology economically achievable, regardless of receiving water condition
- 4. More stringent water quality-based limits may be imposed if technology limits do not protect water quality



# NPDES Permits Regulatory Framework

- Authorized by Clean Water Act Section 402,
   Ohio Revised Code 6111
- Regulated under 40 CFR, OAC 3745



# INDIVIDUAL PERMIT DEVELOPMENT



#### **Process Steps**

- 1. Receive Application
- 2. Completeness Review
- 3. Develop TBELs
- 4. Develop WQBELs
- 5. Apply Requirements
- 6. Develop Monitoring & Reporting Requirements
- 7. Develop Special Conditions

- 8. Incorporate Standard Conditions
- 9. Complete Fact Sheet
- **10.**Public Notice Permit
- 11.Respond to Public and EPA Comments
- **12.**Issue Final Permit



### **Your Application - Deadline**

- New Discharge: Minimum 180 days before discharge starts
  - More time required if AD project
- Existing Discharge: 180 days before current permit expiration date



# **Individual Application Types**

- Form 1: General Information
- Form 2A: POTWs
- Form 2B: CAFOs
- Form 2C: Existing Manufacturing, Commercial, Mining and Silvicultural
- Form 2D: New Manufacturing, Commercial, Mining and Silvicultural
- Form 2E: Non-process Manufacturing, Commercial, Mining and Silvicultural
- Form 2F: Industrial Storm Water
- Form 2S: Sewage Sludge



### **POTW Application - Contents**

- Form 1
- Form 2A
- Form 2F (if applicable)
- Form 2S
- Antidegradation Addendum



# Ohio EPA Review of Your Application

#### Completeness Review

- Correct Forms and CHECK?
- Authorized Signatory (40 CFR 122.22/OAC 3745-33-03)
- Includes Flow and Discharge Data?
- Calculations and Diagrams Correct?
- Any New Pollutants?
- Confidential Information



## Ohio EPA Review of Your Application

- Antidegradation?
- Facility Site Visit
  - Inspect treatment processes/effluent quality
    - Bypasses/Overflows, CSOs, SSOs Frequency of use?
       NFA?
  - May involve sampling by Ohio EPA
  - Pretreatment program review
  - Review laboratory procedures/data quality
  - Important to ask questions/resolve uncertainties



It's all about the....

#### **FACT SHEET**



## **Fact Sheets are Required**

#### 40 CFR 124.8

- Details which facilities must have a Fact Sheet
  - Includes POTWs ≥ 1MGD
- Requires the Fact Sheet include the principal facts, legal, methodological and policy questions
- Details additional requirements for the Fact Sheet
- Descriptive Facts

#### 40 CFR 124.56

- Derivation calculations for specific effluent limits
- Limits for toxic pollutants
- Limits on internal waste streams
- Limits on indicator pollutants
- Site specific limits



#### What about minor facilities

- Includes POTWs < 1 MGD</li>
  - No Fact Sheet
  - All other permitting criteria apply




# Where is my Fact Sheet?






# Where is my Fact Sheet?





# Where is my Fact Sheet?





# What's in My Fact Sheet?

- Location of Discharge
- Facility Description
- Description of Existing Discharge
- Assessment of Impact on Receiving Waters
- Development of Water Quality Based Effluent Limits
- Reasonable Potential/Effluent Limits/Hazard Management Decisions
- Other Requirements



#### Location, Location

- Location of Discharge
- Receiving Water Use Designation
  - OAC 3745-1-08 through -32
  - Aquatic life protection, recreation use and water supply use
- Water Quality Standards
- Other site specific concerns
  - TMDLs



# **Facility Description**

- Design Flow
- Processes Wet Stream and Solids Handling
  - Preliminary Treatment
  - Primary Treatment
  - Secondary Treatment
    - Activated Sludge
    - Trickling Filter
    - Other
  - Tertiary Treatment
  - Anaerobic/Aerobic Digestion
- Bypasses and Overflows
  - -002s
  - -003s



# Description of Existing Discharge (The Devil in the Details)

- Annual Pretreatment Report Data
- DMR data
- WET data
- Projected Effluent Quality (PEQ)



#### **DMR Data**

Table 2. Effluent Characterization Using Self-Monitoring Data

Summary of current permit limits and unaltered discharge monitoring report data for Southerly outfall 3PF00002001 (April 2006 – March 2011). All values are based on annual records unless otherwise indicated. \* = For minimum pH, 5th percentile shown in place of 50th percentile; \*\* = For dissolved oxygen, 5th percentile shown in place of 95th percentile; a = weekly average.

			Current Permit Limits			Perc	entiles	
Parameter	Season	Units	30 day	Daily	#Obs.	50 <sup>th</sup>	95 <sup>th</sup>	Data Range
Water Temperature	Annual	С	Monitor		1826	17.6	24.3	8-25.5
Dissolved Oxygen	Summer	mg/l		5.0	920	7.5	8.6	5.4-9.5
Dissolved Oxygen	Winter	mg/l		5.0	906	9.3	10.9	5.6-12.1
Residue, Total Dissolved	Annual	mg/l	Monitor		1804	705	1230	295-2070
Total Suspended Solids	Annual	mg/l	16	24 <sup>a</sup>	1815	2	5	0-18
Oil and Grease, Hexane	Annual	mg/l		10	130	0	3.11	0-3.7
Nitrogen, Ammonia (NH3)	Summer	mg/l	1.7	2.6	913	0.16	0.5	0.03-1.28
Nitrogen, Ammonia (NH3)	Winter	mg/l	5.0/8.0#	7.5/12 <sup>8#</sup>	874	0.1	0.603	0-3.28
Nitrite Plus Nitrate, Total	Annual	mg/l	Monitor		1788	15	19.8	4.5-23
Phosphorus, Total (P)	Annual	mg/l	1.0	1.5°	1787	0.53	0.94	0.06-1.36
Cyanide, Free	Annual	mg/l	0.0057	0.027	127	0.0015	0.00284	0-0.0045
Nickel, Total Recoverable	Annual	ug/l	Monitor		273	12.5	22	4.6-31.3
Zinc, Total Recoverable	Annual	ug/l	Monitor		273	36	49.8	13.1-66.3
Cadmium, Total Recoverable	Annual	ug/l	Monitor		273	0	0.2	0-0.7
Lead, Total Recoverable	Annual	ug/l	Monitor		273	0	0.64	0-6.1
Chromium, Total Recoverable	Annual	ug/l	Monitor		273	2	3.22	0-6.1
Copper, Total Recoverable	Annual	ug/l	23	43	273	11.8	18.6	3.7-30
Chromium, Dissolved Hexavalent	Annual	ug/l	Monitor		130	0	4.96	0-5.46
Fecal Coliform	Annual	#/100 ml	1000	2000 <sup>a</sup>	915	32	746	0-21400
Flow Rate	Summer	MGD	Monitor		920	90.7	190	66.6-343
Flow Rate	Winter	MGD	Monitor		906	115	253	70.5-381
Flow Rate	Annual	MGD	Monitor		1826	101	233	66.6-381
Chlorine, Total Residual	Annual	mg/l		0.021	943	0	0	0-0.123
pH, Maximum	Annual	S.U.		9.0	1826	7	7.3	6.6-8.3
pH, Minimum	Annual	S.U.		6.5	1826	6.8	7.1	6.5-7.4
Mercury, Total Recoverable	Annual	ug/l	Monitor		60	0.002	0.005	0.001-0.005
CBOD 5 day	Summer	mg/l	10	15 <sup>a</sup>	913	0	3	0-13
CBOD 5 day	Winter	mg/l	16	24 <sup>a</sup>	878	0	4	0-12.9

<sup>#</sup> Winter ammonia limit months - March, April, Nov/Dec, Jan, Feb



#### **Annual Pretreatment Report Data**

Table 1. Effluent Characterization Using Ohio EPA and Pretreatment Data

Summary of analytical results for Southerly outfall 3PF00002001. Units ug/l unless otherwise noted; PT = data from pretreatment program reports; ND = not detected (detection limit); j = estimated value, greater than MDL but less than PQL; MDL = method detection limit; PQL = practical quantification level.

PARAMETER	PT 07/27/10	PT 08/03/09	PT 01/06/08	PT 01/08/08	PT 01/10/08	PT 08/28/07	PT 08/09/06	OEPA 05/03/11
Antimony	1.39	1.86	ND(10)	1.5(j)	0.6(j)	ND(10)	ND(10)	NA
Arsenic	2.44	3.01	ND(20)	1.4(j)	1.7(j)	ND(20)	ND(20)	3.0
Barium	NA	21						
Cadmium	0.09	ND(0.15)	ND(1.0)	0.2(j)	ND(0.2)	ND(1.0)	ND(1.0)	ND(0.20)
Chromium	1.24	1.41	ND(10)	1.6(j)	1.7(j)	ND(10)	ND(10)	2.2
Copper	6.11	4.25	ND(10)	6.8	5.9	ND(10)	ND(10)	6.3
Dissolved solids, total (mg/l)	NA	588						
Iron (mg/1)	NA	90						
Nickel	8.59	9.98	9.97	20.7	11.3	21	29.6	7.6
Selenium	1.52	1.94	ND(10)	2.6(j)	2.8(j)	ND(10)	ND(10)	ND(2.0)
Strontium	NΑ	NΔ	NA	NΔ	NΔ	NΔ	NΑ	2/17



# **Projected Effluent Quality (PEQ)**

- Uses past discharge data to project / anticipate what future discharge will contain
- Conservative (high) values to ensure water quality is protected
- Uses Your DMR Data (and other relevant Ohio EPA Data)



# **PEQs**

Table 3. Projected Effluent Quality Values

Parameter	units	# samples	# >MDI	PEQ	PEQ
			>MDL	average	maximum
Self-monitoring (DMR) data:					
Ammonia (summer)	mg/L	607	607	0.248	0.513
Ammonia (winter)	mg/L	429	429	0.190	0.440
Cadmium, TR	µg/L	273	118	0.358	0.49
Chlorine, total residual	mg/L	943	7	0.00045	0.0006
Chromium, TR	μg/L	273	271	2.62	3.4
Chromium <sup>6+</sup> , Dissolved	μg/L	130	64	3.189	4.36
Copper, TR	μg/L	273	273	15.2	19.
Cyanide, free	mg/L	127	125	0.00259	0.0037
Dissolved Solids	mg/L	1804	1804	809	114
Lead, TR	μg/L	272	33	0.430	0.68
Mercury, TR	ng/L	60	60	3.07	4.2
Nickel, TR	μg/L	273	273	17.55	23.4
Nitrate+Nitrite-N	mg/L	1788	1788	10.08	13.8
Suspended Solids	mg/L	1815	1789	2.91	5.1
Phosphorus, total	mg/L	1787	1787	0.596	0.81
Zinc, TR	μg/L	273	273	43.7	53.
Ohio EPA, Pretreatment and NEORSD					
data:					
Antimony	μg/L	2	2	5.16	7.0
Arsenic, TR	μg/L	3	3	6.59	9.0
Barium, TR	μg/L	1	1	95	13
Bromodichloromethane A	μg/L	1	1	6.4	8.
Bromomethane	μg/L	1	1	6.9	9.
Chloroform A	μg/L	8	2	7.7	10.
Dibromochloromethane A	μg/L	1	1	2.4	3.
Iron, TR	μg/L	1	1	407	55
Selenium, TR*	μg/L	274	274	3.5	4.
Strontium, TR	μg/L	1	1	1118	153
Thallium, TR*	μg/L	252	252	7.0	9.
Toluene	μg/L	8	1	6.9	9.

A Carcinogen



TR=total recoverable

<sup>\* =</sup> NEORSD data

# PEQs: It's Math not Magic!!





#### **PEQs**

- OAC 3745-2-04
- Ohio EPA Modeling Guidance 1
- Two methods to calculate PEQ
  - Method A
  - Method B
- Case-specific
- Pollutant specific



#### **PEQs**

- Methods based on statistics
- "Conservative"
  - Highest potential value
  - Potential based on uncertainty
- Less data → More uncertainty → Higher potential value



- Data set has less than 10 observations
- Data set has less than 5 observations that equal or exceed the analytical detection limit
- Max PEQ = (maximum daily concentration) \* F
- Average PEQ = Max PEQ \* 0.73
  - F = safety/uncertainty factor

N	1	2	3	4	5	8	14	49
F	6.2	3.8	3.0	2.6	2.3	1.9	1.5	1.0



#### Method B

- Data set has 10 or more observations
- Data set has 5 or more observations that equal or exceed the detection limit
- Log normal calculations resulting in 90%
   confidence interval around the 95<sup>th</sup> percentile



- Maximum PEQ = exp (LM + k \* LS)
- Average PEQ for m<10 = exp (LMA + k \* LSA)</li>
- Average PEQ for m≥10 = EX + k \* sqrt (VX/m)

- Where:




- m = number of effluent observations per month
- n = total number of effluent observations
- LM = mean of the natural logs of the daily effluent data
- LS = Standard Deviation of the natural logs of the daily effluent data
- LMA = estimated mean of the natural logs of the monthly averages of the effluent data



- LSA = Estimated standard deviation of the natural logs of the monthly averages of the effluent data
- EX = Estimated long-term mean of the daily effluent data
- VX = Estimated long-term variance of the daily effluent data
  - k = TINV(p, df, nc)/sqrt(n)
- TINV = inverse noncentral t-distribution function








### PEQ using Method A

AA	20	AA	AA	AA	AA	AA	AA
AA	AA	AA	30	21	AA	AA	AH
AA							

- n = 23 (<5 values greater than MDL)</li>
- Max PEQ = (maximum daily concentration) \* F
- Max PEQ = (30)\*1.3 = 39
- Average PEQ = Max PEQ \* 0.73
- Average PEQ = (39)\*0.73 = 28.47



## **PEQ using Method B: Got a Good Computer Program?**



"There it is. You forgot to convert to dog years."



## **PEQ using Method B**

AA	20	AA	AA	AA	10	10	10
AA	AA	AA	30	21	10	10	10
AA	AA	AA	AA	10	10	10	10

- n = 24 (>5 values greater than MDL)
- Max PEQ = 28.13
- Average PEQ = 17.64



#### What Goes Around Comes Around:

#### NPDES PERMIT LIMITS

## BASED ON APPLICATION OF THE MOST STRINGENT TBEL OR WQBEL



#### **Effluent Limits: TBELS**

- Technology Based Effluent Limits
- Represent the minimum national treatment requirements
  - Secondary Treatment Limits
  - Treatment equivalent to secondary
- Developed based on readily available technology
- Consistent limits for each regulated sector
- Takes economics into consideration



#### **POTW Secondary Treatment Regulations**

- 40 CFR Part 133
- BOD<sub>5</sub>/(CBOD<sub>5</sub>)
  - 30-day average shall not exceed 30 mg/L (25 mg/L)
  - 7-day average shall not exceed 45 mg/L (40 mg/L)
  - 30-day % removal shall not be less than 85

#### TSS

- 30-day average shall not exceed 30 mg/L
- 7-day average shall not exceed 45 mg/L
- 30-day % removal shall not be less than 85

#### pH

-6.0-9.0



### Ohio <u>Best Available and Demonstrated Control</u> <u>Technology (BADCT)</u>

- Applies to new or expanded WWTPs(\*)
- 10 mg/L CBOD<sub>5</sub> (30-day average)
- 12 mg/L TSS (30-day average)
- 1.0 mg/L (S)/3.0 mg/L (W) NH3-N (30-day avg.)
- 126/100 ml E. coli (30-day average)
- 6.0 mg/L D.O. (Min.)
- 0.038 mg/L Chlorine (Max.)



## **Effluent Limits: WQBELS**

- Water Quality Based Effluent Limits
- Can be site or water body specific
- Developed to protect water quality standards
- Can not take economics into consideration
  - Well, there are always exceptions
    - Variances



# Development of Water Quality Based Effluent Limits

- Pollutant by Pollutant Basis
- Wasteload Allocation (WLA) Process
- Assimilative capacity (i.e. Available Stream Dilution)



## **Water Quality Standards**

- Human health
  - Drinking water supply
  - Nondrinking water supply
- Wildlife
- Agriculture



## **Water Quality Standards**

#### Aquatic Life

- IMZM inside mixing zone maximum
- OMZM outside mixing zone maximum
- OMZA outside mixing zone average



## **Fact Sheet: Water Quality Criteria**

		Outside Mixing Zone Criteria			<u>ria</u>	Inside
		Average		Maximum	Mixing	
		Human	Agri-	Aquatic	Aquatic	Zone
Parameter	Units	Health	culture	Life	Life	Maximum
Arsenic	μg/L	580.	100.	150.	340.	680.
Bis(2-ethylhexyl)phthalate <sup>c</sup>	μg/L	32		8.4	1100.	2100.
Cadmium	μg/L	730.	50.	3.3	7.0	14
Chlorine	mg/L			0.011	0.019	0.038
Chromium	μg/L	14000.	100.	120.	2500.	5000.
Chromium VI	μg/L	14000.		11	16	31
Copper	μg/L	64000.	500.	13	20.	41
Cyanide - free	mg/L	48.		0.0052	0.022	0.044
Lead	μg/L		100.	11	200.	400.
Mercury AB	ng/L	3.1	10000.	910.	1700.	3400.
Molybdenum	μg/L	10000.		20000.	190000.	370000.
Nickel	μg/L	43000.	200.	73	650.	1300.
Nitrate + Nitrite	mg/L		100.			
Selenium	μg/L	3100.	50.	5		
Silver	μg/L	11000.		1.3	3.1	6.3
Total Filterable Residue	mg/L			1500.		
Zinc	μg/L	35000.	25000.	170.	170.	330.




## **Mixing Zone**

- Where wastewater enters and initially mixes with the stream or water body (dilution area)
- Does not apply to BCCs, e.g. Hg




### **Mixing Zone:**

- Must be as small as feasible
- WQ criteria met at edge/boundary of mixing zone
- Cannot exceed IMZM





#### Mixing Zone: Example





#### **Wasteload Allocations**

- WLA is the effluent limitation calculated for your facility discharge under specified flow conditions
  - Your facility's effluent will not cause a water quality violation if below that value

• "WLA" = "Preliminary Effluent Limit" = "PEL"



## **Wasteload Allocation Inputs**

- WQC = Water Quality Criterion
- Qeff = Effluent Flow
- Qup = % of Stream Design Flow
  - % defined in OAC 3745-2-05
- WQup = Background Water Quality



#### WLA: Streams vs. Lakes

**Flowing Waters** 

**Non-flowing Waters** 

11(WQC) - 10(BACK)



#### **Wasteload Allocations**

Flowing Waters (aka Streams)
 WQC (Qeff + Qup) – Qup (WQup)
 Qeff

• WLA = PEL = 26.2



#### **Wasteload Allocations**

•Non-flowing waters (aka Lakes) 11(WQC) – 10(BACK)

11(13) - 10(1.0)

•WLA = PEL = 133



## **Fact Sheet: WLA Table**

					· ·	
		Ou	Inside			
		Average			Maximum	Mixing
		Human	Agri-	Aquatic	Aquatic	Zone
Parameter	Units	Health	culture	Life	Life	Maximum
Arsenic <sup>B</sup>	μg/L	1362 <sup>A</sup>	231	209	758 <sup>A</sup>	680
Bis(2-ethylhexyl)phthalate	μg/L	75		12	2465 <sup>A</sup>	2100
Cadmium <sup>B</sup>	μg/L	1719 <sup>A</sup>	118 <sup>A</sup>	4.8	16 <sup>A</sup>	14
Chlorine	mg/L		-	0.021	$0.076^{A}$	0.038
Chromium <sup>B</sup>	μg/L	32980 <sup>A</sup>	236	176	5769 <sup>A</sup>	5000
Chromium VI <sup>B</sup>	μg/L	32970 <sup>A</sup>	1	14	30	31
Copper	μg/L	150700 <sup>A</sup>	1172 <sup>A</sup>	17	42 <sup>A</sup>	41
Cyanide – free <sup>B</sup>	mg/L	113 <sup>A</sup>	-	0.007	0.048 <sup>A</sup>	0.044
Lead	μg/L		234	16	479 <sup>A</sup>	400
Mercury <sup>C D</sup>	ng/L	3.1	$10000^{A}$	910	1700	3400
Molybdenum <sup>B</sup>	μg/L	23550		28030	414700 <sup>A</sup>	370000
Nickel <sup>B</sup>	μg/L	101300 <sup>A</sup>	471	106	1497 <sup>A</sup>	1300
Nitrate + Nitrite	mg/L		384			
Selenium <sup>B</sup>	μg/L	7302	118	7		
Silver <sup>B</sup>	μg/L	25910 <sup>A</sup>		1.8	7.5 <sup>A</sup>	6.3
Total Filterable Residue <sup>B</sup>	mg/L			2102		
Zinc	μg/L	82430 <sup>A</sup>	58880 <sup>A</sup>	244	391 <sup>A</sup>	330



# Reasonable Potential: aka "Can you meet the limit"

Average = <u>average PEQ</u> average PEL

 Maximum = maximum PEQ maximum PEL



#### PEQ

- -Method A = 28.47
- Method B = 17.64
- WLA/PEL = Preliminary Effluent Limit (PEL)
  - Flowing Water = 26.2
  - Non-flowing Water = 133



- PEQ from Method A
- PEL from Flowing Water
- Average = <u>average PEQ</u>average PEL
- Flowing Water = 28.47/26.2 = 109%



- PEQ from Method B
- PEL from Flowing Water
- Average = <u>average PEQ</u>average PEL
- Flowing Water = 17.64/26.2 = 67%



## Groupings

- Group 1: No criteria
- Group 2: PEQ < 25%
- Group 3: PEQmax < 50% of maximum PEL and PEQavg < 50% of average PEL</li>
- Group 4: PEQmax >= 50% of PELmax or PEQavg >= 50% of PELavg
- Group 5: PEQmax >= 100% of the PEL



#### **Limits**

- Group 1: No limit
- Group 2: No limit recommended, monitoring optional
- Group 3: No limit recommended, monitoring optional
- Group 4: Monitoring is appropriate
- Group 5: Limit recommended




#### **PEQ Method A**

- n = 23, 3> DL
- PEQ = 28.77
- PEL = 26.2
- RP = 109%
- Group 5
- Limit Required

#### **PEQ Method B**

- n = 24, 13 > DL
- PEQ = 17.64
- PEL = 26.2
- RP = 67%
- Group 4
- Monitoring Only





"Suzie, this is math, not the law."



#### **To Summarize:**

- The higher the Group, the more monitoring you will have to do
- The data you submit is used to determine the Group
- Less "real" data increases the probability of a high Group and permit limit





"Your Honor, I would have concentrated on the facts, but they weren't in my favor!"



### **INTERMISSION**



## So you have a Fact Sheet:



• Now What?



#### NPDES Permit – 5 Main Sections

- Title Page Permittee name and location, permit period, authorizing statement, discharge location.
- Effluent Limits applicable technologybased and water quality-based standards.
- Monitoring and Reporting Requirements



#### **NPDES Permit - 5 Main Sections**

- Other (Special) Conditions
- Standard Conditions (aka "Boilerplate") -Legal, administrative, and procedural requirements of the permit.



Page 1 3PF00002\*MD

Application No. OH0024651

Issue Date: June 28, 2012

Effective Date: August 1, 2012

Expiration Date: January 31, 2017

Ohio Environmental Protection Agency Authorization to Discharge Under the National Pollutant Discharge Elimination System

In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et. seq., hereinafter referred to as the "Act"), and the Ohio Water Pollution Control Act (Ohio Revised Code Section 6111),

Northeast Ohio Regional Sewer District

is authorized by the Ohio Environmental Protection Agency, hereinafter referred to as "Ohio EPA," to discharge from the Southerly Wastewater Treatment Center located at 6000 Canal Road, Cuyahoga Heights, Ohio, Cuyahoga County and discharging to the Cuyahoga River in accordance with the conditions specified in Parts I, II, and III of this permit.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code.

This permit and the authorization to discharge shall expire at midnight on the expiration date shown above. In order to receive authorization to discharge beyond the above date of expiration, the permittee shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.

Scott J. Nally Director

Total Pages: 50




## NPDES Permit Sections: Part I, A.

- Outfall Limit Tables(s)
- 001 discharge to waters of the state
- 002, 003... other direct discharges
- 001:
  - Initial
  - Interim
  - Final



# **Determining Permit Limits**



- CBOD, TSS, pH always
- 0&G, E. coli
- P (1.0 mg/l Lake Erie basin)
- NH3, DO Design/Modeled
- Which other parameters to include:
  - PEQ > 50% but < 100% of WLA,</li>
     Monitoring
  - PEQ > 100% of WLA, Limit



### **Monitoring Tables**

- Header: effective dates
- Parameters (Permit Guidance 1)
- Reporting Codes
- Limits
- Monitoring frequencies
- Monitoring months
- Sample type (grab, composite, 24 hour composite...)
- Footnotes



Page 3 3PF00002\*MD

Effluent Characteristic	Discharge Limitations							Monitoring Requirements		
	Concentration Specified U						•	Measuring	Sampling	Monitoring
Parameter	Maximum 1	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Frequency	Type	Months
01220 - Chromium, Dissolved Hexavalent ug/l		-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	1/Day	Grab	Summer
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50060 - Chlorine, Total Residual - mg/l	0.021	-	-	-	-	-	-	1/Day	Multiple Grab	Summer
50060 - Chlorine, Total Residual - mg/l	0.021	-	-	-	-	-	-	When Disch.	Multiple Grab	Winter
50092 - Mercury, Total (Low Level) - ng/l	1700	-	-	3.1	1.13	-	0.00205	1/2 Weeks	Grab	All
61425 - Acute Toxicity, Ceriodaphnia dubia - TUa	-	-	-	-	-	-	-	2/Year	24hr Composite	June and Oct.
61426 - Chronic Toxicity, Ceriodaphnia dubia - TUc	-	-	-	-	-	-	-	2/Year	24hr Composite	June and Oct.
61427 - Acute Toxicity, Pimephales promelas - TUa	-	-	-	-	-	-	-	2/Year	24hr Composite	June and Oct.
61428 - Chronic Toxicity, Pimephales promelas - TUc	-	-	-	-	-	-	-	2/Year	24hr Composite	June and Oct.
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Continuous	All
61942 - pH, Minimum - S.U.	-	6.0	-	-	-	-	-	1/Day	Continuous	All
70300 - Residue, Total Filterable - mg/l	-	-	-	-	-	-	-	1/Week	24hr Composite	All
80082 - CBOD 5 day - mg/l	-	-	15	10	-	9936	6620	5/Week	24hr Composite	Summer
80082 - CBOD 5 day - mg/l	-	-	24	16	-	15897	10598	5/Week	24hr Composite	Winter

Notes for Station Number 3PF00002001:

- \* Effluent loadings based on average design flow of 175 MGD.
- Winter-1: November, March and April
- Winter-2: December, January and February
- Total residual chlorine See Part II, Item J.
- Total residual chlorine, winter months "When discharging" means monitoring and reporting are required on days when the facility is chlorinating.
- Mercury See Part II, Items S, W, X and Y.
- Free cyanide See Part II, Item R.
- Whole effluent toxicity See Part II, Item U.
- pH minimum See Part II, Item Q.



## **Monitoring Table Details**

#### Pollutant Parameters

- -mg/l,  $\mu g/l$ , ng/l
- contract lab may not report in the same units

#### Sample type

Composite is not the same as 24 hour composite



# **Monitoring Table Details**

#### Monitoring months

Reduced monitoring frequencies

#### Footnotes

- Monitoring months
- Bis(2-ethylhexyl) phthalate
- Free Cyanide
- Low level mercury
- Dissolved P



# To Do List: Read your Draft Permit and Fact Sheet

- Interim and Final Tables
  - Note new/different permit limits explained in fact sheet
  - Coordinate with Compliance Schedule



# To Do List: Read your Draft Permit and Fact Sheet

- New numeric limit?
  - -WLA calculations
  - -Was Method A used?
- Your annual PPS may come back to haunt you



#### NPDES Permit Sections: Part I, B.

#### **Other Monitoring Stations**

- 601 WWTP influent
- 602, 603... WWTP internal (e.g. bypasses)
- 300 sanitary sewer overflows
- 581, 582,... sludge
- 801, 802... upstream
- 901, 902... downstream



#### Part I, B. - INFLUENT MONITORING REQUIREMENTS

7. Influent Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment works' influent wastewater at Station Number 3PF00002601, and report to the Ohio EPA in accordance with the following table. Samples of influent used for determination of net values or percent removal must be taken the same day as those samples of effluent used for that determination. See Part II, OTHER REQUIREMENTS, for location of influent sampling.

Table - Influent Monitoring - 601 - Final

Effluent Characteristic	Discharge Limitations							Monitoring Requirements		
Parameter	Concer Maximum M		Specified I Weekly		Lo Daily	ading* kg/ Weekly	day Monthly	Measuring Frequency	Sampling Type	Monitoring Months
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	5/Week	24hr Composite	All
00720 - Cyanide, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00981 - Selenium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01113 - Cadmium, Total Recoverable - ug/	- 1	-	-	-	-	-	-	1/Month	24hr Composite	All
01114 - Lead, Total Recoverable - ug/l	-	-	-	ŀ	-	-	-	1/Month	24hr Composite	All
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
50092 - Mercury, Total (Low Level) - ng/l	-	-	-	-	-	-	-	1/Month	Grab	All
61941 - pH, Maximum - S.U.	-	-	-	-	-	-	-	1/Day	Continuous	All
61942 - pH, Minimum - S.U.	-	-	-	-	-	-	-	1/Day	Continuous	All
80082 - CBOD 5 day - mg/l	-	-	-	_	-	-	_	5/Week	24hr Composite	All

Notes for Station Number 3PF00002601:

-Sampling shall be performed on the same day as Outfall 3PF00002001.

- Mercury - See Part II, Item S.



#### NPDES Permit Sections: Part I, C.

#### **Compliance Schedules**

- Pretreatment
- Construction
- Previous permit violations
- New limitation imposed (WLA process)



#### Part I, C - Schedule of Compliance

#### A. Municipal Pretreatment Schedule

 The permittee shall evaluate the adequacy of local industrial user limitations to attain compliance with final table limits. Technical justification for revising local industrial user limitations to attain compliance with final table limits, along with a pretreatment program modification request, or technical justification for retaining existing local industrial user limitations shall be submit to Ohio EPA, Central Office Pretreatment Unit, in duplicate, as soon as possible, but not later than 6 Months from the effective date of this permit. (Event Code 52599)

Technical justification is required for mercury. Technical justification is also required for arsenic, beryllium, cadmium, total chromium, dossolved hexavalent chromium, copper, cyanide, lead, nickel, silver and zinc unless screening of wastewater and sludge indicate these pollutants are not present in significant amounts. Furthermore, technical justification is required for any other pollutants where a local limit may be necessary to protect against pass through and interference.

To demonstrate technical justification for new local industrial user limits or justification for retaining existing limits, the following information must be submitted to Ohio EPA:

- a. Domestic/background and industrial pollutant contributions
- b. Treatment plant removal efficiencies
- c. A comparison of maximum allowable headworks loadings based on all applicable criteria. Criteria may include sludge disposal, NPDES permit limits, and interference with biological processes such as activated sludge, sludge digestion, nitrification, etc.
- d. If revised industrial user discharge limits are proposed, the method of allocating available pollutant loads to industrial users
- Supporting data, assumptions, and methodologies used in establishing the information a through d above
- 2. If revisions to local industrial user limitations are necessary the permittee shall incorporate revised local industrial user limitations in all industrial user control documents. This shall be completed not later than 4 months after the date of Ohio EPA approval of the modification request. Within 7 days of completing this requirement, the permittee shall notify, in writing, the Ohio EPA Central Office Pretreatment Unit.



### Part I, C. Details

- Compliance milestones → required report to Ohio EPA
  - Make sure you track those
  - Can lead to SNC
- Due dates based on NPDES permit effective date



# To Do List: Read your Draft Permit and Fact Sheet

- Compliance Schedule
  - Everything in logical order
  - Time allotted for tasks



#### **NPDES Permit Sections: Part II**

#### **Other Conditions**

- Operator of Record
  - Must be designated in writing
- Description of Outfalls and Monitoring Stations
  - Verify that these are correct & representative locations (Lat./Long.)



#### **NPDES Permit Sections: Part II**

#### **Other Conditions**

- 300 Station reporting requirements
  - -24-hour call followed by 5-day report.
- Sludge Station(s) Requirements
  - Annual report (January 31)



# **Part II Other Requirements**

- Monitoring Table Footnotes
  - Bis-2 sample requirements
    - Manual composite in glass
  - Low level mercury methods: EPA 1631, EPA 245.7
  - Dissolved P sample requirements
    - Monthly filtered grab sample
    - Senate Bill 1 (Orc 6111.03) 7/3/2015
    - Renewals/Mods. POTWs ≥ 1MGD



# **Part II Other Requirements**

- Monitoring Table Footnotes
  - Free Cyanide: new approved methods, no longer use weak acid dissociable
  - Samples and detention times
- PQLs (chlorine, etc.)
- You cannot use the monitoring tables correctly without reading Part II



# **Part II Other Requirements**

- Pretreatment
- Biomonitoring
- Mercury Variance
- These usually contain compliance milestones or requirements for your next permit renewal



#### **Part II Pretreatment**

- Program requirements
  - -IU permits, IU monitoring
  - Annual priority pollutant analysis
  - -Enforcement, Reporting



# To Do List: Read your Draft Permit and Fact Sheet

- Part II Pretreatment
  - Use WLA in determining local limits
  - Verify that WLA values most current information (consistent with Fact Sheet)



#### 4. Local Limits

The permittee shall develop and enforce technically based local limits to prevent the introduction of pollutants into the POTW which will interfere with the operation of the POTW, pass through the treatment works, be incompatible with the treatment works, or limit wastewater or sludge use options.

The permittee shall use the following waste load allocation values when evaluating local limits for the following pollutants for which a final effluent limit has not been established:

Arsenic 140 ug/l
Beryllium 45 ug/l
Cadmium 5.2 ug/l
Chromium, hexavalent 12 ug/l
Chromium, total 141 ug/l
Copper 24 ug/l
Free Cyanide 29 ug/l
Lead 64 ug/l
Nickel 119 ug/l
Selenium 5.5 ug/l
Silver 1.4 ug/l
Thallium 18.5 ug/l
Zinc 263 ug/l

#### Control Mechanisms

The permittee shall issue control mechanisms to all industries determined to be Significant Industrial Users as define in OAC 3745-3-01(FF). Control mechanisms must meet at least the minimum requirements of OAC-3745-3-03(C)(1)(c).

#### 6. Industrial Compliance Monitoring

The permittee shall sample and inspect industrial users in accordance with the approved program or approved modifications, including inspection and sampling of all significant industrial users at least annually. Sample collection, preservation and analysis must be performed in accordance with procedures in 40 CFR 136 and with sufficient care to produce evidence admissible in judicial enforcement proceedings.

The permittee shall also require, receive, and review self-monitoring and other industrial user reports when necessary to determine compliance with pretreatment standards and requirements. If the permittee performs sampling and analysis in lieu of an industrial user's self-monitoring, the permittee shall perform repeat sampling and analysis within 30 days of becoming aware of a permit violation, unless the permittee notifies the user of the violation and requires the user to perform the repeat analysis and reporting.



## **Part II Biomonitoring**

- 1/year bioassay (minimum if ≥ 1MGD)
- Important to coordinate with other sampling



#### Part II General Mercury Variance

- Verify that Hg variance limit is appropriate WLA
- Must demonstrate POS implementation
- Must request variance in writing with each permit renewal
- Annual Hg PMP report



#### **Part III General Conditions**

- 32 standard conditions
- "Boilerplate" but
- Important for compliance



#### **Part III Includes:**

- Sampling/Analytical Methods
  - 40 CFR 136 approved methods
  - 40 CFR ≠ Standard Methods
  - Not all EPA methods are EPA approved
- Permitee is responsible for all data, including contract lab data
- Reporting
  - Must have delegation to PIN eDMR/ Lab personnel



#### Part III Includes:

- Facility operation requirements
- Records retention
  - 3 years (Sludge 5 years) unless directed otherwise
- Non-compliance notification
  - 24-hour notification (email preferred)
- Upsets and bypasses



#### **Public Notice**

- 30 Day Public Notice Period
  - Plus 15 days to publish
- Notice Given to
  - Applicant
  - US EPA
  - Interested Parties
  - Newspaper of Largest Circulation
  - Weekly Review
  - Ohio EPA Web



# To Do List: Comment in writing <u>before</u> Public Comment Period ends

- Letter to Central Office
  - Courtesy copy to district contact
- Ask for extension before the last day



# **Comments and Responses**

- Public Notice lists where to send comments
- Ohio EPA Response to Comments
- Public Hearing Request
  - -Significant Public Interest
  - Comment Period Extended



18/NE

Application No.: OH0024643 Ohio EPA Permit No.: 3PF00001\*LD

#### National Pollutant Discharge Elimination System (NPDES) Permit Program

#### PUBLIC NOTICE

#### NPDES Permit to Discharge to State Waters

Ohio Environmental Protection Agency Permits Section 50 West Town St., Suite 700 P. O. Box 1049 Columbus, Ohio 43216-1049 (614) 644-2001

Public Notice No.:

OEPA 11-09-009 DFT

Date of Issue of Public Notice:

Sep-05-2011

Name and Address of Applicant:

Northeast Ohio Regional Sewer District, 3900 Euclid Avenue,

Cleveland, OH, 44115

Name and Address of Facility Where Discharge Occurs:

Easterly STP, 14021 Lakeshore Blvd, Cleveland, OH, 44110,

Cuyahoga County

Outfall Flow and Location List:

01 155,000,000 GPD

41N 34' 15"

81W 35' 22"

Receiving Stream:

Lake Erie

Nature of Business:

Wastewater Collection and Treatment

Key parameters to be limited in the permit are as follows:

CBOD 5 day, Chlorine, Total Residual, Acute Toxicity, Ceriodaphnia dubia, Chronic Toxicity, Ceriodaphnia dubia, E. coli , Fecal Coliform , Mercury, Total (Low Level), Nitrogen, Ammonia (NH3), Oil and Grease, Hexane Extr Method, pH, Maximum, pH, Minimum, Phosphorus, Total (P), Total

Suspended Solids

On the basis of preliminary staff review and application of standards and regulations, the director of the Ohio Environmental Protection Agency will issue a permit for the discharge subject to certain effluent conditions and special conditions. The draft permit will be issued as a final action unless the director revises the draft after consideration of the record of a public meeting or written comments, or upon disapproval by the administrator of the U.S. Environmental Protection Agency. Any person may submit written comments on the draft permit and administrative record and may request a public hearing. A request for public hearing shall be in writing and shall state the nature of the issues to be raised. In appropriate cases, including cases where there is significant public interest, the director may hold a public hearing on a draft permit or permits prior to final issuance of the permit or permits. Following final action by the director, any aggrieved party has the right to appeal to the Environmental Review Appeals Commission.



#### **Issue Final Permit**

 Draft Permit normally includes proposed Effective Date

Effective Beginning of Month



# To Do List: After final permit issued

- Note changes
- Significant changes from Draft discussed in written response



- Note all reporting requirements
  - Infrequent, unusual samples
  - -Part I., C. Schedule of Compliance
  - -Part II



- Monitoring months
- Sample type
- Special sample requirements
- Reporting units
  - -mg/l,  $\mu g/l$ , ng/l



- Sample early in the month
  - -Sampling problems
  - Result violates monthly average



- Coordinate WET, TDS, metals, ammonia
- WET common causes:
  - -TDS (c. dubia)
  - -Ammonia



- Make sure you have NPDES permit limits and WLA values available for easy reference
  - -WLA Table from Fact Sheet
    - "Summary of Effluent Limits to Maintain Applicable Water Quality Criteria"
  - —Don't forget WET WLA



- Pay attention to how results are reported
  - Contract lab may not report in same units as NPDES permit
  - -MDL vs. PQL



#### MDL vs. PQL

- MDL = Method Detection Level
  - Value where 99% certain pollutant is present
  - Uncertain actual concentration
- PQL = Practical Quantification Level
  - Certain actual concentration
  - Usually 3 to 5 times MDL
- MDL required by NPDES Permit
- PQL > Limit or WLA



- Compare your sample results to WLA table values
  - –Result > NPDES Permit Limit
  - -Result > WLA
  - –Detection level ≥ WLA



# "AA" isn't Enough

- What is the MDL?
- MDL > Permit Limit → Maybe it isn't a violation of the permit limit, but maybe it is; you can't prove your discharge was below the limit
- Cadmium Permit Limit is 3.2  $\mu$ g/l, your result is AA, MDL = 5.0  $\mu$ g/l



# "AA" isn't Enough

- What is the MDL?
- MDL > WLA → Maybe your discharge didn't violate water quality standards, but maybe it did
- Cadmium WLA is 3.2 µg/l, your result is AA,
   MDL = 5.0 µg/l



# **Problem Parameters**

- Cadmium, TR
  - OMZA 2.5 7.3 μg/l
- Lead, TR
  - $-OMZA 6.4 37 \mu g/l$
- Hexavalent Chromium, Dissolved
  - $-OMZA 11 \mu g/l$



# **Problem Parameters**

- Selenium, TR
  - $-OMZA 5.0 \mu g/l$
- Silver, TR
  - $-OMZA~1.3~\mu g/l$
- Bis(2-ethylhexyl)phthalate
  - $-OMZA 8.4 \mu g/l$



# Low Level Mercury

- Investigate high results, esp. for effluent
  - Unusual sample conditions?
  - Include test blanks and get results
  - Grab = "snapshot in time"



# Question Anything Questionable

- Check computations
- Ask about lab operations
  - –Recent equipment failure/calibration/maintenance?
  - –Sample collection and handling?
- Did the sample appear different?



- If results reported incorrectly, notify us in writing/email
- If sampling performed incorrectly, notify us in writing/email



- Always submit corrected DMRs
- If POTW operations change significantly, notify us in writing/email



- DMR, PPS data used for NPDES permit renewal
  - Previous 5 years unless good reason to use different time period



- High sample results reported
  - Reporting error by you or lab
  - Contaminated sample
  - Sample not representative

NPDES permit limit



- High detection levels
  - Skew the data set in Method B
  - -Result in high PEQ in Method A



- If the DL > WLA, there will be additional monitoring in the new NPDES permit
  - Part II language specifying detection level

(BTW, you've wasted five years of sampling and analysis costs)



# Don't Forget

- Part 1,C commitments
  - Local limits
  - Other compliance schedule items
- Mercury variance requirements
- Required reports



#### **Detection Levels Info**

PP Form Recommended Detection Levels
 Division of Surface Water -> Quick Link
 "Pretreatment Program" -> Approved
 Pretreatment Programs -> Forms for Approved
 programs -> Recommended Detection Levels
 for Priority Pollutant Scans



#### **Detection Levels Info**

 "Limits Below Quantification Level" Permit Guidance 9

http://www.epa.state.oh.us/Portals/35/guida nce/permit\_9.pdf



#### **REMEMBER:**

# Ohio EPA uses *your data* to develop the NPDES Permit

What goes around comes around



#### **Questions?**

**Erm Gomes** 

330.963.1196

Erm.gomes@epa.ohio.gov

**Donna Kniss** 

330.963.1285

Donna.kniss@epa.ohio.gov

