



29 June 2017

The State of Enhanced High-Rate Treatment in Ohio

Tony Yee, PE
Project Manager
MSDGC

Jared Hutchins, PE
Engineering Manager
Black & Veatch

BUILDING A WORLD OF DIFFERENCE®



BLACK & VEATCH

What is EHRT?

Settling-Based	Filtration-Based	Flotation-Based
1. Conventional Settling -Rectangular, Circular, Square, RTB, Shaft	1. Shallow Granular Media	1. Conventional Floatables Removal -Skimmers, Scum baffles
2. Vortex (Swirl Concentrator)	2. Deep Granular Media	
3. Lamella Settler	3. Microscreens, Woven Media -Salsnes Filter, Eco MAT™ Filter	2. Dissolved Air Flotation (DAF)
4. Chemically Enhanced Settling	4. Floating Media -MetaWater HRFS, BKT BBF-F	
a. Conventional Basin		
b. Sequencing Batch - e.g. ClearCove Flatline EPT		
c. Lamella Settler		
d. Solids Contact / Recirculation - e.g. DensaDeg®, CONTRAFAST®	5. Pile Cloth Media -Aqua-Aerobic Systems	3. Polymer-aided DAF -Various suppliers
e. Ballasted Flocculation - Microsand (e.g. ACTIFLO®, RapiSand™) - Magnetite (e.g. CoMag™)	6. Compressible Media -Fuzzy Filter™, WWETCO FlexFilter™	
5. Suspended Growth Contact -BIOACTIFLO™, BioMag™, Bio-CES	7. Fixed-Film Contact -Biological Aerated Filter (BAF), BioFlexFilter™	4. Biocontact + DAF -Captivator®

Primary Removal Equivalent *


Small Footprint (High-Rate Treatment)

Enhanced Removal


* If coagulation/flocculation provided, HRT → EHRT (in some cases)



Augment Existing WRRF with EHRT




ROAD TRIP!




- **NEORS - Chemically Enhanced Primary Treatment + High Rate Disinfection**
- **Toledo - High Rate Clarification**
- **Springfield - High Rate Filtration**
- **Cincinnati - Chemically Enhanced Settling & Emerging Technologies Piloting**



NEORSD Westerly WWTC & Full-Scale CEHRT Plan




SIMCED Trial Included



Credit: Brown and Caldwell (2016)




NEORSD – Westerly CEHRT Pilot Plan




Credit: Brown and Caldwell (2016)

Major Findings



- Successful CEPT operation at SOR of 10,500 gpd/sf
- Consistent CEPT effluent TSS of <30 mg/L achieved over wide range of operations
- Simultaneous CEPT and HRD in single tank with no reduction in TSS removal performance



CEHRT successful at achieving NEORSD CD goals over wide range of operating conditions



232 mgd EHRT Facility
Vortex Grit Removal
HRC - Ballasted Flocculation
Reaeration
Chlorination
Dechlorination


195 mgd Activated Sludge WRF

25 MG Storage Basin

Toledo Bay View WRF



High Rate Clarification with Solids Recirculation



232-mgd in ~130' x 270'

Central Gallery
Process Piping
Sludge Pumping

3 DensaDeg[®] Units

3 DensaDeg[®] Units

Polymer Feed
Tanks and
Pumps

Coagulant
Feed Tanks
and Pumps



Performance of Toledo EHRT

Operating Mode	Pollutant	Influent Concentration		Effluent Concentration		Percent Removal	
		Range mg/L	Average mg/L	Range mg/L	Average mg/L	Range %	Average %
<i>Primary & Excess Flow Treatment (Units 2-6)</i>	Ammonia	1.8 – 3.2	2.4	1.8 – 3.1	2.4	<0 – 22	0
	TKN	2.9 – 12.9	6.3	2.0 – 7.0	4.5	5 – 64	28
	CBOD	20 - 77	42	10 – 27	16	22 – 82	54
	Suspended CBOD	10 - 66	31	2 – 21	9	12 – 93	64
	TSS	19 - 440	131	9 - 66	18	<0 – 97	74
	Total P	0.6 – 2.1	1.1	0.2 – 0.5	0.2	64 – 90	79

Excellent TSS and Phosphorus Removal



100 mgd EHRT Facility

25-mgd ADF Activated Sludge WWTP

Wet Weather Headworks Channel and Rock Box Flow Splitting Horizontal Bar Screens




Springfield WWTP

13



Compressible Media Filtration

- Synthetic fibers bundled together into ~1.5” spheres
- ~30” bed depth
- Porosity altered by compression
- Removal down to 4 microns
- 10+ year filter media life




100-mgd in 120' x 320'

**NaOCl and
NaHSO₃ Storage
and Feed**

**11 Cell
Compressible
Media Filter**

Effluent Pumps


**10 Minute
NaOCl
Contact Tank**
**Backwash Pumps
Backwash Blowers
Sampler
Electrical/Control Room**



Performance of Springfield EHRT

Effluent Averages *		
TSS	mg/L	16
CBOD ₅	mg/L	21
NH ₃ -N	mg/L	2.5
TP	mg/L	0.6
DO	mg/L	8.7
TRC **	mg/L	0.02
E. Coli	#/100 mL	56

* 42 events 3/3/15 – 5/12/16
 ** NaOCl avg dose = 4 mg/L




Excellent Effluent Quality and Disinfection




MSDGC EHRT – Chemically Enhanced Sedimentation

Tony Yee, PE & Jared Hutchins,
PE



MSDGC Service Area & CSO 522






Combined Sewer Overflow 522

- Highly active CSO
- Community priority due to sewer debris and odors in residential setting
- Wide range of flows up to 1,400-mgd
- Targeted for Demonstration EHRT in Phase 1 WWIP

WWEHRTF Process Schematic



106-mgd in ~150' x ~250'

Future Expansion

Disinfection Contact Tank

Mixed Mode

CES Train

Influent Control Structure

FeCl₃, Polymer,
NaOCl and
NaHSO₃ Storage
and Feed

Influent Pump
Station


Screenings Room

Existing CSO 522
Location

Werk Road



Influent Control Structure




- Dissipate energy
- Direct flows into facility up to peak treatment capacity, and release excess flows to creek
- Promote solids clean-up post event for odor control
- No dry weather flow
- Provides coarse screening and floatables control




Influent Fine Screens

- Chain and Rake
- ½" Aperture Size
- 2 x 53 mgd
- 40% Blinding Factor
- Direct Discharge to Screenings Container

Rugged Screening Equipment for High Leaf Loads




Influent Pump Station



- Submersible, non-clog
- Two large (35-mgd), two small (18-mgd), spare slot for 5th pump
- Level-controlled, adjustable speed
- Trench-style wetwell

Delivers flow to CES and Disinfection





CES and Disinfection/Dechlorination

- Individual, enclosed rapid mix, flocculation, sedimentation and disinfection zones
- Sedimentation 3:1 L:W, SOR 7,000 gpd/sf @ 35-mgd
- Disinfection 15 min CT @ 35-mgd, 10 min @ 53-mgd
- Mixed mode channel for fine screening and disinfection only



WWEHRTF Construction

Future Expansion

Disinfection Contact Tank

Mixed Mode

CES Train

FeCl₃, Polymer,
NaOCl and
NaHSO₃ Storage
and Feed

Influent Control Structure


Influent Pump
Station

Screenings Room



Existing CSO 522
Location

Werk Road

Westbourne Dr.



Emerging EHRT Technologies Pilot



Emerging EHRT Technologies Pilot Results

Pile Cloth Media

- 2.5 to 6.7 gpm/sf HLR
- Avg. effluent TSS 18 mg/L
- Avg. TSS removal 77%
- Relatively constant and effective TSS removal across wide range of events

Floating Media

- 16.9 to 27.6 gpm/sf HLR
- Avg. effluent TSS 56 mg/L
- Avg. TSS removal 51%
- More variable TSS removal during pilot study

Both systems appear capable of TSS removal at full-scale EHRT



BUILDING A WORLD OF DIFFERENCE

29 June 2017

Tony Yee

+1 513-244-5180

Anthony.Yee@cincinnati-oh.gov

Jared Hutchins

+1 513-936-5137

HutchinsJC@bv.com

BUILDING A WORLD OF DIFFERENCE®



METROPOLITAN
SEWER DISTRICT
of greater
CINCINNATI



BLACK & VEATCH