



IMPROVING THE HOCKING WITH CSO REDUCTION AND ADVANCED TREATMENT TECHNOLOGY

Presented by:

Kimberly Seidelmann, PE,
ARCADIS

Mike Nixon
City of Lancaster

October 12, 2017



Agenda

- Project Background
- Upper Hocking Pump Station
- Upper Hocking WPCF
 - Wet Stream Processes
 - Solids Handling Processes



CITY OF LANCASTER

Project Background

City of Lancaster, OH Collection System

- **Population Served ~ 38,780**
- **225.5 Miles of Sanitary Sewer**
- **12.3 Miles of Combined Sewer**

Lawrence St. WPCF

- **Average Flow ~ 6.0 mgd**
- **Peak Capacity – 18 mgd**

Project History

1995 – Began Sewer System Capacity Evaluation

- Developed system model, addressed basement flooding

1997 – NPDES Permit

- System Operational Plan – March 1998
- System Characterization Report – Dec 1999
- Long Term Control Plan – June 2000

2003 – NPDES Permit

- Long Term Control Plan Addendum – March 2005
 - Addressed four major CSOs

2007 – NPDES Permit

- Lake /Allen/Maple Sewer Separation – Feb 2009
- Upper Hocking Water Pollution Control Facilities – Dec 2011
- Phase II Long Term Control Plan – March 2014

To Date 24 of 33 CSOs eliminated

CSO Planning

Lake /Allen/Maple Sewer Improvement

- Completed in 2008

Upper Hocking Water Pollution Control Facilities

- Completed in 2011

Flow Monitoring/Phase II Long Term Control Plan

- Flow Monitoring Report to OEPA in January 2014
- Submit Phase II LTCP to OEPA by March 2014


Broad Street Express Sewer

- Completed May 2016

19 other proposed projects for CSO reduction in the future

Key Projects for CSO Reduction

Collection System – Service Areas



Upper Hocking Water Pollution Control Facilities

Summary of New Facilities

Upper Hocking WPCF

- 2.0 mgd (ADF) Water Pollution Control Facility – to treat separately sewerred areas only.

Upper Hocking Pump Station

- Remote 8.0 mgd (peak) Pump Station and force mains – to divert flow from separately sewerred areas to the new WPCF

Schedule

Construction Began – January 2009

Startup – July, 2011


Construction Cost – \$36 Million

Upper Hocking Water Pollution Control Facilities

Construction of the Upper Hocking Water Pollution Control Facilities served to:

- intercept and provide full secondary treatment for selected separate sewer areas prior to entering combined sewer system
- Reduce combined sewer overflow volume
- Accommodate new growth along US 33 Bypass corridor and northwest side of City

Upper Hocking Facilities – Sewer Separation



UPPER HOCKING PUMP STATION


Upper Hocking Pump Station

- **Capacity**
 - Firm – 8.0 mgd
 - Average ~ 1.7 mgd
 - Minimum ~ 0.4 mgd
- **Wet pit/dry pit style**
- **Self-cleaning trench wet well**
- **Manual bar rack**
 - (2 –inch spacing)
- **Five dry pit submersible pumps**
 - Two larger pumps ~ 5 mgd
 - Three smaller pumps ~ 2 mgd



Upper Hocking Pump Station

- **Odor Control**
 - Biofilter
 - Chemical addition to force mains
- **Standby Diesel Generator**
- **Dual force mains**
 - 14 inch and 18 inch – 14,000 ft. of each
 - Ductile iron
 - Pigging
 - HDPE at stream and railroad crossings (directional drill)
 - 3 locations



Upper Hocking Pump Station

- **Aesthetics**

- Architecture and landscaping to blend with surrounding highly commercial area

- **Telemetry**

- Radio communication
- Overall pump station control system
- Critical data interfaces with Upper Hocking WPCF control system

UPPER HOCKING WATER POLLUTION CONTROL FACILITY

Upper Hocking WPCF – Flow Rates

Peak Flow Through Preliminary Treatment – 8.0 mgd

Design Flows Through Secondary Treatment

- Average Daily Flow Rate – 2.0 mgd
- Minimum Flow Rate – 0.4 mgd
- Peak Monthly Flow Rate – 3.5 mgd
- Peak Daily Flow Rate – 6.0 mgd
- Peak Hourly Flow Rate – 6.0 mgd
 - Maximum flow limited by membrane

Currently Average Daily Flow Rate – 1.3 mgd

Upper Hocking WPCF – Effluent Limits

- **NPDES Effluent Limits**


	Monthly	Weekly
CBOD ₅	10 mg/l	15 mg/l
TSS	12 mg/l	18 mg/l
NH ₃ -N (Summer)	1.5 mg/l	1.0 mg/l
NH ₃ -N (Winter)	4.5 mg/l	3.0 mg/l
E Coli (Summer)	161/100 ml	62/100 ml
DO	6.0 mg/l minimum continuous	

- **Additional Effluent Goals**

	Monthly	Weekly
Total Phosphorous	1.0 mg/l	1.5 mg/l
Turbidity	0.2 NTU	0.2 NTU

Wet Stream Processes

- Influent Fine Screening
- Equalization
- Aeration Process (Vertical Loop Reactors)
- Membrane Bioreactors
- UV Disinfection
- Post Aeration



Preliminary Treatment – Fine Screening

Influent Fine Screens:

- Fine screening critical for protection membrane life
- 2 units each rated for 8 mgd
- Internally-fed rotary drum screens
- 2 mm perforations

Screenings Washer Compactors:

- 1 per screen
- Discharge to truck/container below



Preliminary Treatment – Equalization

Equalization Tank:

- Volume – 1 million gallons
- Contain all flows in excess of 6 mgd
- Wastewater pumped to VLRs
- Jet mixing system
 - 2 pumps
 - Jet diffusers



Process Aeration – Vertical Loop Reactors

Three VLR basins


Dimensions

- Width – 30 ft, Depth – 20 ft, Length – 66 ft
- Volume – 285,000 gal each
- HRT – 10.3 hours (design average)
- SRT – 49 days (design average)

MLSS concentration – 7,000 to 10,000 mg/l

Basins generally operate in series

- VLR 1A – anoxic zone
- VLR 1B and 1C – aerobic
- Total nitrogen removal




Membrane Bioreactors (MBRs)

Membrane Bioreactors Selected:

- Superior effluent quality
- Discharges to Hocking River just upstream of the City of Lancaster
- With plant expansions, future discharge limits may be stricter because of low flow in stream
- High level of automation, minimum staff attention
- Takes less space than conventional clarifiers
- More reliable solids separation performance
- Eliminates need for filters
- Easily expandable
- Potential for effluent reuse at industrial park

Membrane Bioreactors (MBRs)



Membrane Bioreactors (MBRs)

Membrane Bioreactors

- Tanks – 3 each
- Dimensions:
 - 25' x 15.75' x 9.22' D
- Volume – 77,646 gal each
- Racks per tank – 17
- Module per rack – 16
- Module per tank - 272



Membrane Bioreactors (MBRs)

Three tanks rated for 2 mgd (peak) each

Composed of vertical membrane cartridges

Siemens hollow fiber membranes


- Membrane pore size: 0.1 microns
- (0.0001 mm)
- Membrane material - Polyvinylidene fluoride



The picture can't be displayed.

Membranes

Pore Size 0.1 microns – Ultrafiltration



Process

– Membrane Bioreactors

Cleaning Processes

- Relaxation
 - Stop filtration (filtrate pumps)
 - Removes caked solids from membranes
 - 60 seconds for every 12 minutes
- Sodium Hypochlorite Maintenance Clean
 - 300 ppm sodium hypochlorite
 - Every 7 days
 - Removes biologicals from inside of membranes
- Sodium Hypochlorite Clean-in-Place
 - 1500 ppm sodium hypochlorite
 - Removes biologicals from outside of membranes
 - Every 90 days
- Citric Acid Clean-in-Place
 - 2 percent citric acid
 - Removes mineral buildup from outside of membranes
 - Every 90 days



Disinfection, Post-Aeration, P Removal

Ultraviolet Disinfection

- Trojan 3000+
- Low pressure, high output
- Not in use as long as Fecal Coliform is maintained. Must be loaded and ready

Post Aeration

- Step aeration
- Dissolved oxygen requirement – 6 mg/l

Phosphorous Removal

- Design allowed for for Chemical addition
- 1 mg/l goal
- Currently monitoring and reporting, but no current limit



Upper Hocking WPCF – Water Quality

- Average Influent Characteristics**

	CBOD₅ (mg/l)	TSS (mg/l)	TKN (mg/l)	NH₃-N (mg/l)	TP (mg/l)
Average from 2016	181.3	312.4	38.1	22.97	6.9

- Average Effluent Characteristics**

	Flow (mgd)	CBOD₅ (mg/l)	TSS (mg/l)	NH₃-N (mg/l)	TP (mg/l)	E. Coli (cfu/100ml)	Nitrate/ Nitrite (mg/l)
Average from 2016	1.3	<2.68	<1.75	<0.56	2.11	9	5.23

Solids Handling Processes



Cannibal® (Evoqua) Sludge Minimization Process

- Ultra fine screens
- Grit removal
- Two sludge conditioning tanks (Interchange Tanks)

Two Interchange (Sludge Storage) Tanks


Centrifuge

The Cannibal® Process



- **Mixed liquor is conditioned by ORP control in a sidestream process to minimize waste sludge**
 - Sidestream process promotes growth of facultative bacteria which are then fed back to VLRs
 - Standard digestion produces 0.6 to 0.7 lbs solids/lbs BOD treated
 - Cannibal reduces biological yield to 0.28 lbs solids/lbs BOD treated


The Cannibal® Process



RAS Rotary Drum Screen


- 0.25 mm
- **Wedgewire**
- Removes:
 - Inerts and trash

Washer Compactor




The Cannibal® Process – RAS Screening

- *Screens out trash, inerts, and non-biodegradable solids*
- *Screenings from approximately 44 hours of operation*
- *RAS screenings volume 4 to 5 times more than influent screenings*





The Cannibal® Process – Grit Removal



- **Grit Pump**
- **Cyclones**
 - Separate by specific gravity
 - Intermittent use based on plant conditions
 - Removes fine grit/inerts



The Cannibal® Process – Interchange Tanks




Tanks are filled once per day on alternating days

MLSS is returned to the VLRs (1/10th of sludge by dry weight)

- Decanter – keeps the proper solids content
- Coarse Bubble Diffusers – controlled by ORP readings
- Floating Mixer


The Cannibal® Process – Solids Yield

Running Composite Yield



Influent BOD₅ Loading

Influent BOD₅



Dewatering

Dewatering Centrifuge

- Andritz D4LL
- Minimum Solids Capture: 95%
- Feed Concentration: 1 – 3 %
- Cake Solids Concentration: 20 %
- Currently Landfilling Biosolids
 - 168 dry tons of bio solids annually



Dewatering

*20% +/- Biosolids
at Lawrence Street WPCF*



*20% +/- Biosolids
at Upper Hocking WPCF*



Questions?

Kimberly Seidelmann, PE

Senior Project Engineer

Arcadis
100 E. Campus View Blvd, Suite 200
Columbus, Ohio 43235

(614) 985-9224
Kimberly.Seidelmann@arcadis.com

Mike Nixon

Water and Wastewater Superintendent

City of Lancaster, Ohio
Water Pollution Control Facilities
800 Lawrence Street
Lancaster, Ohio 43130

(740) 687-6664
mnixon@ci.lancaster.oh.us



Evoqua Video

<http://www.evoqua.com/en/brands/Memcor/Pages/mempulse-mbr.aspx>