

Energy Audits Waste Water Treatment Plants

Ohio Water Environment Association Conference

June 20, 2012


Presented by:

Samuel J. Morgan, P.E., LEED AP

CT Consultants, Inc.

World Energy Trend

Figure 15. World energy consumption by fuel, 1990-2035
(quadrillion Btu)




U.S. Energy Information Administration, *International Energy Outlook 2011*, September 19, 2011.

US Total Energy Usage

	Quadrillion BTU	
□ Residential	22.2	23%
□ Commercial	18.2	19%
□ Industrial	30.1	31%
□ Transportation	27.5	28%
□ TOTAL	98.0	

US Total Energy Usage Chart

Quadrillion BTU



Total = 98 Quadrillion BTU


- Residential
- Commercial
- Industrial
- Transportation

US Electric Energy Usage

	Quadrillion BTU	
□ Residential	5.0	39%
□ Commercial	4.5	35%
□ Industrial	3.3	26%
□ Transportation	0.3	0.2%
□ TOTAL	12.8	

US Electric Energy Usage Chart

Quadrillion BTU



Total = 12.8 Quadrillion BTU

- Residential
- Commercial
- Industrial
- Transportation

Energy Benchmarking

- Commercial Buildings
 - Energy Star
 - DOE Commercial Buildings Benchmark
 - LEED
 - USGBC – US Green Building Council
 - ASHRAE
 - 90.1 Defines Minimum Energy Efficiency Standards
 - 189.1 Allows Adoption of LEED as Building Code

Energy Benchmarking

- WWTP – EPA Tools
 - Energy Star EPA Portfolio Manager – WTP & WWTP
 - EPA Energy Management Planning Self Assessment Worksheet
 - EPA Groundwater and Drinking Water Energy Use Assessment Tool

EPA Benchmarking Tools for WWTP

- EPA Energy Star Portfolio Manager
 - Performance Score Based on Energy Use per Unit of Flow / Effluent Quality / Treatment Type
 - Accessed On-line
- EPA Energy Use Assessment Tool
 - Drills Down to Equipment Level
 - Allows Utility Bill Analysis
 - Use Before Full Scale Energy Audit _

Non-EPA Benchmarking Tools

- WERF Carbon Heat Energy Analysis Plant Evaluation Tool (CHEApet) – for WERF Members
---- Water Environment Research Foundation ----
- CEE Water and Wastewater Self-Audit Checklists
---- Consortium for Energy Efficiency ----
- NYSERDA Water and Wastewater Focus Program
- Various State Specific Measurement Tools

Electric Usage at WWTP and WTP

- 55 Billion Kilowatt Hours (kWh)
- \$4 Billion Annual Energy Cost
- Equivalent to 45 Million Tons of Greenhouse Gas
- Represents 3% of US Electricity Use
- Accounts for 35% of Municipal Electric Use
- Preliminary Savings Estimates = 15% - 30% _

WWTP Energy Use

- Over 15,000 Wastewater Treatment Plants
- Over 50,000 Water Treatment Plants
- WWTP Energy = 25% – 35% of Total Plant O&M _

Why Reduce?

- Reduced Energy Costs
- Lower Operating Costs
- Save Water
- Reduced Carbon Footprint
 - Lower Greenhouse Gas Emissions


Reduce Carbon Footprint

- Saving 25% of WWTP Energy Equals
 - 9,500,000 Tons CO₂
 - 3,300,000 Tons Recycled Waste Instead of Landfill
 - 22,000,000 Million Barrels of Oil
 - 51,500 Rail Cars of Coal
 - 1,180,000 Homes
 - Carbon sequestered by 2,000,000 Acres Pine Forest

Where Does the Energy Go

End Use	% of Total
Raw Sewage Pumping	12%
Aeration	55%
Anaerobic Digestion	11%
Clarifiers	3%
Solids Handling	8%
Buildings, HVAC, Lighting	6%
Other	5%

WWTP Energy Usage



Types of Energy Audits

- Varying Level of Detail
- Varying Level of Costs
- ASHRAE Tiered Levels
 - Level 1 – Walk-Through Analysis, Low or No Cost
 - Level 2 – Energy Survey Req'd, Identifies Energy Conservation Measures with Cost Estimate & Payback
 - Level 3 – Detailed Analysis of Capital Intensive Improvements _

Types of Energy Audits

□ ASHRAE Level I

- Walk-through Analysis Identifies Areas of Potential Energy Savings
- Usually ½ Day or Less
- Suggestions for Quick Payback Projects
- Suggestions for Areas Needing Further Study
- Often Performed for Little or No Cost _

Types of Energy Audits

- ASHRAE Level II
 - May Require One or Two Days at Plant
 - Includes Interviews with Plant Personnel
 - May Require Two or More Weeks to Analyze Utility Data, Pump Curves, Aeration Processes, Other Processes
 - Identify Projects With Short Payback
 - Determine Savings, Costs and Payback Period _

Types of Energy Audits

- ASHRAE Level III
 - May Require Three or More Days at Plant
 - Examines Energy Use in All Processes
 - Proposes Possible Design Modifications
 - Emphasis on Optimization
 - Detailed Cost Est. Often with Significant Investment
 - May Result in Major Energy Savings _

Elements of Level II & III Energy Audit

- Examine and Analyze Utility Bill / Rate Structure
 - Electric, Gas and Water
 - Allocate Usage to Major Processes – *Energy Balance*
- Identify Cost Effective Equipment Efficiency Improvements
- Identify Cost Effective Operational Improvements
 - Often Find Controls Related Improvements (e.g. DO)
- Develop Cost Estimate and Energy Savings
- Determine Payback in Years

Work Product - Level II & III Audit

- Whole Plant Benchmark
- Energy Balance
 - Allocate Electric, Gas and Water to End Use
 - Include 24 Months Usage -- 12 Months Minimum
- Energy Conservation Measures
 - Cost of Implementation -- Level II vs. Level III
 - Energy Savings – Include Methods / Calculations
 - Calculate Payback
- Recommendations for Future Study

Energy Audit Focus

- HVAC / Mechanical Systems
 - Mainly in Administrative Buildings
- Electrical Systems
 - Lighting in All Buildings – Examine Efficiency / Consider Occupancy Sensors
 - Motor Efficiency (Premium Motor Efficiency Savings)
 - VFD's (Frequent Savings Opportunities)

Energy Audit Focus

- Aeration Systems
 - Blower Efficiency
 - Blower Controls
 - Constant Speed, Throttling, VFD's
 - Diffusers – Fine Bubble vs. Coarse Bubble



Energy Audit Focus

- Pumping Systems
 - Premium Motor Efficiency
 - Sizing
 - VFD's



- Solids Handling
 - Varies by Plant

Energy Audit Focus - Equipment

- Equipment Assessment
 - Tour Facility
 - Review Plans & Specs
 - Meet with Operating Personnel
 - Understand Current Conditions
 - Discuss Alternatives to be Considered
 - Develop Payback for Each Alternative

Energy Audit Focus - Process

- Process Optimization
 - Review O&M Manual
 - Discuss Operating Techniques
 - Review / Discuss Regulatory Status
 - Consider Present & Future NPDES Discharge Limits
 - Examine Plant Loadings vs. Future Expansion
 - May Develop Computer Model - Benchmarking

Energy Audit Focus - Process

- Process Optimization Continued
 - Explore Revising Basic Plant Operating Methods
 - Analyze Process Configuration Changes
 - Calculate Capital Improvement Costs
 - Calculate Energy Savings
 - Determine Payback Period
 - Identify Other Benefits – Chemical Reduction, Sludge Removal, etc.

Energy Audit Focus – Utility Optimize

- Utility Optimization
 - Examine Utility Rate(s)
 - Consider Alternative Rate Structures - *Case Study 2*
 - Perform Energy Balance – End Use Allocation
 - Examine Incentives to Reduce Peak Demand
 - Evaluate Opportunities to Reduce Peak Demand

Energy Audit Focus – Buildings

- Building Auditing
 - Allocate Energy to End Use
 - HVAC
 - HVAC Controls
 - Lighting
 - Envelope

Auditor's Tools

- eQuest
- Air Master +
- Motor Master +
- Pumping Assessment Tool (PSAT)
- Numerous Others

Analysis of Implementation Costs

- Auditor Must Help Explore Funding Opportunities
- Identify All Utility Incentive Programs
- Factor External Funding and Utility Incentives into Financial Analysis
- Consider Remaining Useful Life
 - Sometimes Overlooked in Energy Audit
 - Include in Capital Replacement Program

Best Savings Opportunities

- Aeration Blower Optimization
 - Control DO to Minimum Practical Value
 - Match Energy Input to DO
 - Via Throttling, Timers, Speed Control
 - Change Diffusers from Coarse Bubble to Fine



Best Savings Opportunities

- Plant Pumping Systems
 - Size for Efficient Operation at Average Conditions
 - Consider Entire System Design
 - Big Pipes and Small Motors - Not the opposite
- Motors
 - Premium Efficiency Motors
 - Apply Variable Speed Drives

Best Savings Opportunities

- Plant Anaerobic Digestion
 - Can Usually Reduce Mixing
 - Run Mechanical Mixers Intermittently
 - Consider Running Heater Recirculation Pumps Intermittently
 - Replace Recessed Biosolids Pumps with Semi-open Impeller Non-clogging Pumps
 - Shift Operations to Off-peak Times Where Possible

Best Savings Opportunities

- Lighting
 - Replace T12 Fluorescent and Incandescent
 - Add Occupancy Sensors
- HVAC in Administrative Buildings
- Water Heating

Case Study 1 – City of Canton Water Reclamation Facility



Case Study 1

Canton Water Reclamation Facility

- De-nitrification Activated Sludge Process
- 39 MGD
- Major Facility Improvement Project
- Install New MBR - Membrane Bioreactor System
- Convert Blowers From Activated Sludge Aeration to MBR Scour Operation

Case Study 1

Canton Water Reclamation Facility Aeration

- 4 – 800 hp Blowers and 1 – 500 hp Blower
- Centrifugal Blowers
- 4160 Volt Motors
- Common Air Header
- Inlet Valve Throttling
- Controlled by Header Pressure


Case Study 1 - VFD's vs. Throttling

- ❑ Should VFD's be Added?
- ❑ If Yes, How Many VFD's? (1, 2, 3, 4 or 5)
- ❑ Blower Type: Centrifugal
- ❑ Blower Motors: 4160 VAC, 3570 RPM
- ❑ Blower HP: 4 – 800 hp + 1 – 500 hp
- ❑ VFD's at 4160 volts Are Very Costly
- ❑ Involve Blower Manufacturer in Analysis

Case Study 1 – VFD's vs. Throttling

- Required SCFM Based on Total Plant Flow (Q)
- Q - Determines Number of MBR Basins
- MBR Basins – 5 Minimum, 12 Maximum
- Developed Hourly SCFM Requirements
- 12,000 – 48,000 SCFM @Outlet Pressure = 7.1 psi
- Derived Number of Blowers for Each Air Flow
- Could Reach All Operating Points with 2 VFD's

Case Study 1 – Fan Performance



Case Study 1 – Fan Laws

- Fan Air Flow Rate Varies with Fan Speed Ratio
 - $Q2 = Q1 \times (N2 / N1)$
- Fan Pressure Varies with Square of Speed Ratio
 - $P2 = P1 \times (N2 / N1)^2$
- Fan Input Power Varies with Cube of Speed Ratio
 - **$H2 = H1 \times (N2 / N1)^3$** ←
 - This 3rd Law Answers Why Speed Control Saves So Much Energy

Case Study 1 – HP vs. Blower Speed

SCFM	RPM	HP	% Full RPM	% Full HP
16,900	3,357	571	100%	100%
14,002	3,300	511	92%	90%
12,402	3,170	441	89%	77%
10,950	3,090	393	87%	69%
9,662	3,025	351	85%	62%
7,754	2,960	298	83%	52%
4,696	2,925	225	82%	39%
Source = Gardner Denver Fan Curves				7.1 psi

Case Study 1 – Air Demand Profile

Hours / Day	SCFM	Blower RPM			
		VFD's		Constant Speed	
		Blower 1	Blower 2	Blower 3	Blower 4
3	12,084	3150	----	----	----
2	22,472	3150	3150	----	----
7	31,270	3225	----	3570	----
12	48,336	2925	2925	3570	3570
0.7	72,504	3560	3560	3570	3570
500 HP Blower Not Shown					

Case Study 1 – Air Demand vs. HP

Hours / Day	SCFM	HP per Blower				Total HP
		VFD's		Constant Speed		
		Blower 1	Blower 2	Blower 3	Blower 4	
3	12,084	430	--	--	--	430
2	22,472	402	402	--	--	804
7	31,270	471	--	675	--	1,146
12	48,336	255	255	675	675	1,800
0.7	72,504	670	670	675	675	2,690
500 HP Blower Not Shown						

Case Study 1 – Annual Energy Cost

Month	kWh	Energy Cost	kWh	Energy Cost
	Inlet Valve Throttling		2 VFD's	
January	807,025	\$ 60,285	736,681	\$ 55,030
February	727,650	\$ 54,355	663,726	\$ 49,580
March	807,814	\$ 60,344	737,711	\$ 55,107
April	779,434	\$ 58,224	710,886	\$ 53,103
May	879,286	\$ 65,683	709,436	\$ 52,995
June	851,698	\$ 63,622	688,436	\$ 51,426
July	880,038	\$ 65,739	711,262	\$ 53,131
August	878,834	\$ 65,649	708,340	\$ 52,913
September	851,071	\$ 63,575	686,914	\$ 51,312
October	878,784	\$ 65,645	708,218	\$ 52,904
November	778,714	\$ 58,170	709,946	\$ 53,033
December	804,657	\$ 60,108	733,593	\$ 54,799
TOTALS	9,925,005	\$ 741,398	8,505,147	\$ 635,334
Annual Savings with 2 VFD's			1,419,858	\$ 106,063

Case Study 1 – Study Results

Blower Curves Defined Operating hp and kW	
Cost per kWh	\$0.075
Energy Cost Inflation	4%
Install Cost of Two VFD's	\$497,000
Annual kWh with Throttling	9,946,000
1 st Year Energy Cost with Throttling	\$742,000
Annual kWh with Two VFD's	8,512,000
1 st Year Energy Cost with Two VFD's	\$635,000

Case Study 1 – Study Results

- 1st Year Gross Energy Savings Using 2 VFD's
 - 1,434,000 kWh
 - \$106,000
 - 14% Reduction
- VFD Rejected Heat at Full Load = 63 mBTU
- 1st Year Cooling Costs for VFD's
 - 107,015 kWh
 - \$8,782

Case Study 1 – VFD's vs. Throttling

□ 1st Year Net Savings

- 1,326,985 kWh

- \$97,218

- 13% Reduction

- Equivalent to 915 Metric Tons of CO₂ Emissions _

Case Study 1 – Payback Calculation

Year	Investment Less Savings + 5% / yr.	Electric Savings + 4% / yr.	Balance End of Year
0	\$ 497,000	\$ 97,282	n/a
1	\$ 521,850	\$ 101,173	\$ 420,677
2	\$ 441,711	\$ 105,220	\$ 336,491
3	\$ 353,316	\$ 109,429	\$ 243,887
4	\$ 256,081	\$ 113,806	\$ 142,275
5	\$ 149,389	\$ 118,358	\$ 31,031
6	\$ 32,583	\$ 123,092	(\$ 90,510)

Payback Period is 5.3 Years

Case Study 1 – Conclusion

- VFD's vs. Inlet Valve Throttling
 - VFD Speed Control is Economically Justified
Even If Inlet Valve Throttling Already Installed
- Blowers Operate Closer to Surge Line
- Savings Produces \$100,000 + Every Year After Year 6
- Savings Calculated Without Utility Incentive

Case Study 2 – City of Willoughby WWTP



- Conventional Activated Sludge Process
- 9 MGD

Case Study 2 – City of Willoughby WWTP

- Performed a Level 1-1/2 Audit
 - Three Hour On-site Visit
 - No Cost to Client
 - Palmer Conservation Consulting & CT
- Looked for Readily Apparent Savings Opportunities
- Developed Some ECM and Calculated Payback
 - Not Normally Part of Level 1 Audit

Case Study 2 - Opportunities

- Savings Opportunities
 - Lighting and Lighting Controls Throughout Plant
 - Administrative Building HVAC Roof Top Units
 - Administrative Building HVAC Controls
 - Power Distribution - Utility Electric Service
 - Secondary Metering to Primary Metering
 - Aeration Blower Dispatch with DO Monitoring

Case Study 2 - Lighting

□ Lighting Upgrade

- Plant Previously Replaced 50% of T12 Fluorescent
- Replace Remaining T12's with T8's
- Applied Utility Incentive -- Minimal
- Calculated 6 Year Payback

□ Lighting Controls

- Occupancy Sensors with Manual Override
- Calculated 6 Year Payback

Case Study 2 - Buildings

- HVAC in Administrative Building
 - Replace Singular RTU with Two Separate Units to Serve Areas of Different Needs
 - Replace Building Controls
 - Approximately \$60,000 in Cost
 - Calculated 10 Year Payback

Case Study 2 – Electric Rate Schedule

- Existing Electric Utility Service
 - 13.2 kV Service from Utility
 - 13,200 – 480 volt Transformers
 - Billing Metering CT's on 480 volt Bus (Secondary)
- Proposed Service
 - Purchase Transformer from Utility Company
 - Move Metering to 13.2 kV Bus (Primary Metering)
 - Savings Due to Lower Electric Rate Schedule

Case Study 2 – Electric Rate Schedule

- Primary Metering Rate is Lower but Has Risks
- Cost to Purchase Transformer and Primary Metering CT's & PT's
 - \$189,000
- Annual kWh Savings = 0
- Annual Electric Cost Savings = \$25,000
- Simple Payback = 7.6 Years

Case Study 2 – Energy Conservation Measures

Energy Conservation Measures	Cost	Annual Savings	Payback – Yrs.
Lighting	\$25,100	\$4,200	6.0
HVAC Modifications	\$43,200	\$4,300	10.0
HVAC Controls	\$27,000	\$2,500	10.8
Power Distribution	\$189,000	\$25,000	7.6
Other	\$27,000	\$1,000	27.0
TOTAL	\$311,300	\$37,000	8.4
Future Study	DO Controls / Aeration Blower Controls		

Case Study 2 – Future Study

- Aeration Blower Dispatch Optimization
- 4 – 200 hp Turbo Blowers
- Manual DO Readings
- Manual Dispatch of Blowers
- Question – If 160% of Blower Capacity is Needed, What is Optimum Configuration?
 - 2 Blowers @ 80% or 1 Blower @100% + 1 @ 60%
 - Other Combination(s) ?

Renewable Energy

- Consider Renewable Energy Alternatives
 - Co-Generation
 - Photovoltaic
 - Wind Turbine
- Usually Requires Outside Funding
 - Often Partially Available
- City of Delphos WWTP
 - Installed 83 kW Photovoltaic - 100% Outside Funding

Summary

- ❑ Energy Costs Will Continue to Increase
- ❑ Perform Level II or Level III Audit
- ❑ Make Energy Conservation an Integral Part of Plant Operations and Future Planning
- ❑ Select Efficient Equipment
- ❑ Install Energy Monitoring Equipment
- ❑ Savings Opportunities Exist —



Thank You