



MASTER PLANNING NEW PHOSPHORUS LIMITS & ASSET MANAGEMENT NEEDS

Dayton, Ohio

Water Reclamation Facility

Presenters:












Nick Dailey P.E., City of Dayton

Sharon Vaughn, City of Dayton


Peter Kube P.E., Arcadis

Prepared for the 2019 Ohio WEA
Technical Conference & Expo


Associate firms

	<p>CAD Concepts Inc. (CCI)</p>	<p>Electrical Assessment</p>
	<p>Kabil Associates</p>	<p>Structural Assessment</p>
	<p>PCS Technologies</p>	<p>I&C Assessment</p>
	<p>Gerkin Swafford Engineering Solutions</p>	<p>Civil/Mechanical Assessment, Project Management Assistance</p>
	<p>Jones-Warner Consultants</p>	<p>Surveying, Utility Locating, Forcemain cost planning</p>
	<p>Automated Systems Engineering (ASE)</p>	<p>Electrical Engineering</p>
	<p>Burgess & Niple</p>	<p>Asset Management Assistance</p>
	<p>Andromeda Systems Inc. (ASI)</p>	<p>Reliability Centered Maintenance</p>
	<p>EmNet</p>	<p>Collection System Modeling</p>
	<p>Webster Environmental Associates</p>	<p>Odor Control</p>
	<p>Bowker & Associates</p>	<p>Odor Control QA/QC</p>


Dayton Wastewater Final Infrastructure




Population anticipated to drop




Dayton Water Reclamation Facility (WRF)



Why Master Plan?



Approach



Approach

1. Required to → Control Phosphorous, Improve odors
2. Need to → Maintenance/Replacement Projects
3. Should do → Status Quo or Replacement Alternatives or Sweeping change
4. Complete → Ongoing Projects

**Advance all 4 simultaneously
and then evaluate best path forward**

Determine the metrics: Establish Levels of Service

Criteria for each process, what it HAS to do

1. Provides firm metrics/“rules” by which alternatives must abide, which
2. enables a fair comparison between alternatives

Examples Level of Service Statements:

1. Flows: plant flows , component flows
2. *Digesters:*
 - *Maintain temperature of 98-degrees Fahrenheit in all digesters.*
 - *All recirculated digester feed to be at 98-degrees Fahrenheit (+/- 1 F).*
 - *For disposal solutions involving land application, achieve a Class B stabilized biosolid. (15 days SRT at Max Month Flow)*
 - *Process max month solids production with two digesters out of service (one east and one west out of service).....”*

Phosphorus Limit Received

OEPA set the limit based on 1 mg/L

Page 8
1PF00000*OD

Effluent Characteristic	Discharge Limitations						Monitoring Requirements			
	Parameter	Concentration	Specified	Units	Loading* kg/day		Measuring	Sampling	Monitoring	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Frequency	Type	Months
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	1/Day	Grab	Summer
39100 - Bis(2-ethylhexyl) Phthalate - ug/l	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50060 - Chlorine, Total Residual - mg/l	0.035	-	-	-	-	-	-	1/Day	Multiple Grab	Summer
50092 - Mercury, Total (Low Level) - ng/l	1700	-	-	12	0.464	-	0.00328	1 / 2 Weeks	Grab	All
51173 - Cyanide, Free (Low-Level) - ug/l	92	-	-	30	25.1	-	8.18	1 / 2 Weeks	Grab	All
51451 - Phosphorous, Total - Kg	131.64	-	-	-	-	-	-	1/Year	Calculated	December
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Continuous	All
61942 - pH, Minimum - S.U.	-	6.5	-	-	-	-	-	1/Day	Continuous	All

g. Phosphorus seasonal loading - Phosphorus, Total - Kg (Parameter Code 51451) is actually a calculated seasonal loading in "kilograms"

although it is listed under a maximum concentration limit. Calculate the seasonal loading as follows: [median daily effluent flow (MGD) for period July 1 - October 31] x [median total phosphorus concentration (mg/l) for the period July 1 - October 31] x 3.7854. Round the result to two decimals and enter the calculated loading for this parameter in eDMRs once during the month of December. Also, see Part II, Item BB.

Current Phosphorus concentrations


Typical Phosphorus Concentrations July 1 - October 31			
Min	Usual Range Lower limit	Usual Range Upper Limit	Max
mg/L	mg/L	mg/L	mg/L
0.28	1.0	3.0	4.0

~ 20% of samples below 1.0 mg/L

~70% in usual range 1.0 to 3.0 mg/L


~10% of sample above 3.0 mg/L

Process Modeling to evaluate proposed solutions



GPS-X Modeling Software by Hydromantis

The paramount tool for this Master Plan




Additional Process Lab Testing

Weekly Sampling and Analytical Requirements for Wastewater Characterization										
Location	Influent	North Primary Effluent	South Primary Effluent	Combined TF Effluent @ Low Lift PS	East Hummus Tanks Effluent	West Hummus Tanks Effluent	Final Settling Tank Combined Effluent	Plant Effluent	Centrifuge Centrate	GBT Filtrate
Sampling Station -->	1	4	5	6a	6	NEW	8	10	grab	grab
TSS	5x	5x	5x	5x	5x	5x	5x	5x	5x	5x
VSS	5x	5x	5x	5x	5x	5x			2x	2x
COD	5x	5x	5x	5x	5x	5x	5x	5x	2x	2x
sCOD(GF)	5x	5x	5x	5x						
ffCOD	5x	5x	5x	5x				5x		
TBOD5	5x									
sTBOD5(GF)	5x									
NO3 at end of TBOD test	5x									
CBOD5	5x	5x	5x	5x	5x	5x	5x	5x		
sCBOD (GF)	5x	5x	5x	5x						
TKN	5x	5x	5x	5x	5x	5x	5x	5x	2x	2x
sTKN (GF)	5x									
NH3-N	5x	5x	5x	5x	5x		5x	5x	2x	2x
NO3-N				5x				5x		
NO2-N				5x				5x		
TP	5x	5x	5x	5x	5x	5x	5x	5x	2x	2x
sTP (GF)										
PO4-P	5x			5x	5x			5x	2x	2x
Alk	5x									
Dissolved Sulfide	5x									

Color Legend:

- currently collected parameter, no change in normal sampling frequency
- currently collected parameter, increased sampling frequency
- new parameter

Testing Data used to calibrate model



Modeled Alternatives



2.2.4 LS-EC-1 –

2.2.5 LS-EC-1 –

Primary Clarification Alternative

2.4.1 Alternative LS-PC-1 –

2.4.2 Alternative LS-PC-2 –

2.4.3 Alternative LS-PC-3 –

Baseline Alternative -

2.5.1 Alternative LS-CA-1 –

Phosphorus Removal Alternative

2.6.1 Alternative LS-PR-1 –

2.6.2 Alternative LS-PR-2 –

2.6.3 Alternative LS-PR-3 –

Combined Nitrogen and Phosphorus

2.7.1 Alternative LS-NR-1 – I

2.7.2 Alternative LS-NR-2 –

2.7.3 Alternative LS-NR-3 – C

2.7.4 Alternative LS-NR-4 – Si

Secondary Treatment Investigation

2.8.1 Investigation LS-ST-1 –

2.8.2 Investigation LS-ST-2 –

2.8.3 Investigation LS-ST-3 –

2.8.4 Investigation LS-ST-4 –

2.8.5 Investigation LS-ST-5 –

Pretreatment of Industrial Discharges Alternatives

2.9.2 Alternative LS-PT-1 –

2.9.3 Alternative LS-PT-2 –

2.9.4 Alternative LS-PT-3 –

Effluent Filters Alternatives

2.10.1 Alternative LS-EF-1 –

2.10.2 Alternative LS-EF-2 –

Disinfection Alternatives

2.11.1 Alternative LS-DI-1 –

2.11.2 Alternative LS-DI-2 –

Phosphorus Control

Three practical methods:

1. Chemical Addition
2. Biological Nutrient Removal
3. Phosphorus Recovery

Chemical Addition Phosphorus Control

Addition of Phosphorus Sequestering Chemical into water:

Typical Locations:

1. After Aeration Basins
2. After Biosolids Dewatering
3. At Primary Clarifiers (Careful!)


Chemical Addition Jar Test



- Multiple chemicals
- Multiple plant locations
- Multiple doses
- Multiple tests
- Multiple people

4 Chemicals Tested

- Aluminum Chloride
- Polyaluminum Chloride (PACL)
- Ferric Chloride
- Rare Earth Metal



Chemical Addition Costs

Chemical Unit Costs Quotes

Chemical	Cost per wet pound (\$/lb)	Cost per gallon (\$/gal)
Ferric Chloride (a)	0.14	2.05
Ferric Chloride (b)	0.093	1.08
Alum (a)	0.1175	1.21
Alum (b)	0.08	0.90
PACI	0.165	1.80
Rare Earth Metal	0.68	8.80

Estimated Yearly Chemical Costs for Phosphorus Control to 1 mg/L

Chemical	Dose Ratio (lb chemical/ lb ortho-P)	Ortho-P to be removed (lb/day)	Chemical Dose Required (lb/day)	Daily Chemical Cost (\$/day)	Annual Chemical Cost (\$/year)
Ferric Chloride	12.6	487	6,119	569	208,000
Alum	21.6	487	10,513	841	306,000
PACI	15.8	487	7,683	1,268	463,000
Rare Earth Metal	13.8	487	6,707	4,651	1,665,000


Estimated Yearly Additional Sludge Hauling Costs for Phosphorus Control to 1mg/L

Chemical	Sludge Generated (lb/day)	Daily Cost (\$/day)	Annual Cost (\$/day)
Ferric Chloride	4,836	79.34	28,960
Alum	3,034	49.78	18,168
PACI	5,233	84.85	31,333
Rare Earth Metal	2,418	39.67	14,480

For Costs: Sludge Hauling wasn't as influential as chemical

Ferric Chloride target range Example

Ortho-P (mg/L) per Dose of Ferric Chloride



To drive Ortho-P removal closer to 0 requires exponentially more Ferric Chloride.

Control Phosphorus Using BNR


BNR

- Biological Phosphorus Removal (BioP), or
- Biological Nitrogen & Phosphorus Removal (TN)
- Control (starve or feast) Oxygen and Mixing to encourage Biology to Uptake Phosphorus ...then remove/waste the Biomass quickly before it releases the phosphorus.
- Step feed to maximize aeration basin capacity during wet weather

Step Feed

Legend


- IPS Flow Modifications
- RAS Flow Modifications



TN Removal

Legend

- Structural Modifications
- Process Modifications



TN with Step Feed

Legend

- Structural Modifications
- Process and IPS Flow Modifications
- RAS Flow Modifications

REMOVE (OR SEPARATE)
DIFFUSERS FROM ALL ANOXIC
ZONES AND REPLACE WITH
MIXING ONLY
PROPOSED
BAFFLE FOR
ANOXIC ZONE
SEPARATION
(TYP)


EXTEND
EFFLUENT
CHANNEL FOR
NEW AERATION
BASINS

EXTEND
INFLUENT
CHANNEL FOR
NEW AERATION
BASINS

PROPOSED
RELOCATED
NORTH
AERATION
BUILDING


10TH AERATION BASIN
POTENTIALLY NOT
REQUIRED BUT MAY BE
CONSTRUCTED FOR
FUTURE USE AND
SYMMETRY

FOR STEP FEED
PIPING
DESCRIPTIONS SEE
ALTERNATIVE LS-PR-2



Control Phosphorus with P extraction and Recovery

Excluded for two main reasons:
Nutrient Recovery is most financially feasible behind BNR and Dayton adds ferric to sequester H₂S for their air emissions permit which also binds phosphorus



Should BNR be implemented in the future, P recovery could be revisited

Results of Phosphorus Removal Alternatives Evaluation

Status Quo- No longer compliant
 20-year Life Cycle

	Status Quo	Alternative LS-PR-2 Step Feed and Chemical Phosphorus Removal	Alternative LS-PR-3 Biological Phosphorus Removal	Alternative LS-NR-2 Step Feed with Nitrogen Removal and Partial Chemical Phosphorus Removal
Construction Cost (\$2018)	\$4,408,000	\$33,255,000	\$38,462,000	\$52,294,000
Annual Chemical Costs	\$0	\$223,000	\$0	\$45,000
Annual Energy Costs	\$851,000	\$912,000	\$936,000	\$1,017,000
Annual Maintenance Costs	\$521,000	\$875,000	\$997,000	\$1,109,000
Total Annual Costs (\$2018)	\$1,372,000	\$2,010,000	\$1,933,000	\$2,171,000
NPV Chemical Costs	\$0	\$3,531,000	\$0	\$706,000
NPV Energy Costs	\$13,462,000	\$14,438,000	\$14,808,000	\$16,093,000
NPV Maintenance Costs	\$8,242,000	\$13,851,000	\$15,782,000	\$17,542,000
NPV Replacement Costs	\$492,000	-\$3,534,000	-\$4,485,000	-\$6,039,000
Total Costs over Present Worth Period	\$22,196,000	\$28,286,000	\$26,105,000	\$28,302,000
Life Cycle Cost (\$2018)	\$26,604,000	\$61,541,000	\$64,567,000	\$80,596,000

Odor Control



Asset Management

Asset Management is a body of **management practices** that...



Targets the **acceptable level of risk** to the organization



Delivers **service levels** customers desire and regulators require



Applies to the **entire portfolio of infrastructure assets** at all levels of the organization



Seeks to **minimize total costs** of acquiring, operating, maintaining, and renewing assets




Works within an environment of **limited resources**




EPA / WERF/ WaterRF Framework

1. What is the current state of my assets?



2. What is the required LOS?



3. Which assets are critical?

4. What are my best CIP and O&M strategies?

5. What is my best funding strategy?

Leading Practice Concepts of Asset Management for Capital Planning



Levels of Service Based on Customer and Stakeholder Expectations



Risk Management Based on Likelihood and Consequence of Failure



CIP Using Life Cycle Cost, Business Cases and Prioritization



Leading Practice Asset Management

Dayton's Condition Assessment



2 Weeks



10 People (Tablets)



3,989 Assets in 46 Categories



2 Facilities (WRF & PS)



Condition Assessment Tools

fulcrum Software
mobile location leverage



Visual Condition Assessment - Overall Scoring Approach

Score	Description
1 - Excellent	Fully operable, well maintained, and consistent with current standards. Little wear shown and no further action required.
2 – Good	Sound and well maintained but may be showing slight signs of early wear. Delivering full efficiency with little or no performance deterioration. Only minor renewal or rehabilitation may be needed in the near term.
3 - Moderate	Functionally sound and acceptable and showing normal signs of wear. May have minor failures or diminished efficiency with some performance deterioration or increase in maintenance cost. Moderate renewal or rehabilitation needed in near term.
4 - Poor	Functions but requires a high level of maintenance to remain operational. Shows abnormal wear and is likely to cause significant performance deterioration in the near term. Replacement or major rehabilitation needed in the near term.
5 – Very Poor	Effective life exceeded and/or excessive maintenance cost incurred. A high risk of breakdown or imminent failure with serious impact on performance. No additional life expectancy with immediate replacement needed.

Performance Assessment

Stepped through each treatment area and discussed each components performance,


maintenance history,

opinion of remaining useful life


- Division Manager
- Plant Administrator
- Plant Engineer
- Treatment Supervisor
- Operation Supervisors
- Supervisor of Maintenance
- Supervisor of Electrical



Asset Management- Assembling a sequential List



Asset Management -Assembling a sequential List



	Project Name	Proposed CIP Year	Equipment Cost	Labour (20%)	Material Cost	Construction Markup (20%)	Capital Cost in 2028 Dollars
1	East Side Roof Repair	Year 03	150,120.00	30,024.00	123,120.00	24,624.00	98,596.00
2	CIP Wastewater - Intermediate Region - Mechanical Repair #1	Year 03	297,800.00	59,560.00	238,240.00	47,648.00	285,888.00
3	CIP Wastewater - Intermediate Region - Structural Repair #1	Year 03	172,200.00	34,440.00	137,760.00	27,552.00	165,312.00
3	CIP Public Systems CIP #1	Year 03	8,473,220.00	1,694,644.00	6,778,576.00	1,355,715.20	8,134,291.20
4	CIP Wastewater - Intermediate Region - Mechanical Repair #2	Year 03	443,800.00	88,760.00	355,040.00	71,008.00	426,048.00
4	CIP Wastewater - Intermediate Region - Structural Repair #2	Year 04	54,300.00	10,860.00	43,440.00	8,688.00	52,128.00
4	Chrysler East HVAC CIP #1	Year 03	370,000.00	74,000.00	296,000.00	59,200.00	355,200.00
4	Chrysler Building CIP #1	Year 03	4,125.00	825.00	3,300.00	660.00	3,960.00
4	Chrysler Building CIP #2	Year 03	1,750,000.00	350,000.00	1,400,000.00	280,000.00	1,680,000.00
5	Primary South North Showers CIP #1	Year 03	34,000.00	6,800.00	27,200.00	5,440.00	32,640.00
5	Primary South North Showers CIP #2	Year 03	34,000.00	6,800.00	27,200.00	5,440.00	32,640.00
6	Chrysler Office Bldg. CIP #1	Year 03	140,200.00	28,040.00	112,160.00	22,432.00	134,592.00
6	Chrysler Office CIP #2	Year 04	4,200.00	840.00	3,360.00	672.00	4,032.00
6	Chrysler Training - Intermediate CIP #1	Year 04	30,000.00	6,000.00	24,000.00	4,800.00	28,800.00
7	Chrysler Office CIP #2	Year 04	444,911.00	88,982.20	355,928.80	71,185.76	427,114.56
7	Chrysler Training - Intermediate CIP #2	Year 04	2,472,000.00	494,400.00	1,977,600.00	395,520.00	2,373,120.00
8	Chrysler Plant CIP #1	Year 04	13,200.00	2,640.00	10,560.00	2,112.00	12,672.00
8	Chrysler Plant Station #1 - Roof CIP #1	Year 04	73,000.00	14,600.00	58,400.00	11,680.00	70,080.00
8	Chrysler Plant Station #1 - Roof CIP #2	Year 04	46,400.00	9,280.00	37,120.00	7,424.00	44,544.00
9	Chrysler Overhead Roof CIP #1	Year 04	76,200.00	15,240.00	60,960.00	12,192.00	73,152.00
9	Chrysler Roof CIP #2	Year 04	499,000.00	99,800.00	399,200.00	79,840.00	479,040.00
10	Chrysler West Roof CIP #1	Year 04	21,400.00	4,280.00	17,120.00	3,424.00	20,544.00
10	Chrysler West Roof CIP #2	Year 04	93,140.00	18,628.00	74,512.00	14,902.40	89,414.40
11	Chrysler Station Tanks CIP #1	Year 04	3	0.60	2.40	0.48	2.88
11	Chrysler Station Tanks CIP #2	Year 04	47,000.00	9,400.00	37,600.00	7,520.00	45,120.00
12	Chrysler North Roof CIP #1	Year 04	4,200.00	840.00	3,360.00	672.00	4,032.00
12	Chrysler North Roof CIP #2	Year 04	43,800.00	8,760.00	35,040.00	7,008.00	42,048.00
12	Chrysler Building Roof CIP #1	Year 04	73,022.00	14,604.40	58,417.60	11,683.52	70,101.12
13	Chrysler Building Roof CIP #2	Year 04	44,400.00	8,880.00	35,520.00	7,104.00	42,624.00


Result is a Sequential List of Asset Maintenance Projects

- Remaining Useful Life based on:
- Years in Service
 - Adjusted Estimated Useful Life (EUL)
 - General Asset EUL
 - Physical Condition
 - Asset Age/Expended Life

Alternatives for Treatment Areas

1. Liquid Treatment Train
2. Solids Treatment Train
3. Odor Control
4. Preliminary Treatment
5. Pumping
6. Electrical & Standby Power
7. Instrumentation & Control
8. Gas & Energy Use
9. Non-Potable Water

Alternatives Brainstormed



Example of Alternatives for Thickening Process:



1. Status Quo: known deficiencies = DAF capacity and obsolescence
- ~~2. Additional DAF in new building → not cost-effective~~
3. Rotary Drum Thickeners (RDTs)
4. Centrifuges
5. Gravity Belt Thickeners (GBTs)

Potential Improvements:

6. Replace TWAS pumps with larger pumps

Alternatives Evaluated and Costed

1. Further investigated to conceptual engineering level
2. Triple bottom line scored: Environmental, Social, Financial
3. Best Scoring Alternative Selected



Tying it all together: Project Priority List

Asset Management

Process Area Alternatives Analyses

Risk Based
Schedule & Sequence

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.
- 7.
- 8.
- 9.
- 10.
- 11.
- 12.
- 13.
- 14.
- 15.

Logical
Priority
Levels

Liquid Stream Alternatives

- A
- **B**
- C

Solids Stream Alternatives

- D
- **E**

Odor Control Alternatives

- F

Preliminary Treatment

- **G**
- H
- I

Pumping

- **J**
- K

Electrical & Standby Power

- **L**

Instrumentation and Control
(SCADA)

- Status Quo

Non-Potable Water

- Status Quo

Tying it all together: Project Priority List



Logical
Priority
Levels


- **Priority Level 0:** Projects already Underway (IPS Pumps, Final Clarifier Mechanism Replacement, etc.)
- **Priority Level 1:** Projects required for an Immediate Regulatory Need (phosphorus limit driven).
- **Priority Level 2:** Critical Asset Management.
- **Priority Level 3:** Projects for Financial Gain (Selling of Biogas for profit)
- **Priority Level 4:** Projects supporting typical Regulatory Needs
- **Priority Level 5:** Projects Providing an Identified Benefit (aka. Potential Improvement projects).
- **Priority Level 6:** Projects for Asset Management and Existing Capacity/Future Capacity.
- **Priority Level 7:** Projects supporting Predicted Regulatory Need (expected in 10 years).

Conceptual Implementation Plan

Conceptual Implementation Plan Sequential Project List

- B- Liquid Stream Highest Scoring Alternative
 - 1. Asset
 - 2. Asset
- E- Solid Stream Highest Scoring Alternative
 - 3. Asset
 - 4. Asset
 - 5. Asset
 - 6. Asset
- J- Pumping Highest Scoring Alternative
 - 7. Asset
 - 8. Asset
 - 9. Asset
 - 10. Asset
 - 11. Asset
 - 12. Asset
- G – Preliminary Treatment Highest Scoring Alternative
 - 13. Asset
 - 14. Asset
 - 15. Asset

Results in
the
following
spend &
schedule




Conceptual Implementation Plan

Conceptual Implementation Plan Sequential Project List

- B- Liquid Stream Highest Scoring Alternative
 - 1. Asset
 - 2. Asset
- E- Solid Stream Highest Scoring Alternative
 - 3. Asset
 - 4. Asset
 - 5. Asset
 - 6. Asset
- J- Pumping Highest Scoring Alternative
 - 7. Asset
 - 8. Asset
 - 9. Asset
 - 10. Asset
 - 11. Asset
 - 12. Asset
- G – Preliminary Treatment Highest Scoring Alternative
 - 13. Asset
 - 14. Asset
 - 15. Asset

Loaded into
Financial
Model

Financial Model



Conclusion

- Regarding Odors:
 - Installing Biofilters for Odor Control at Trickling Filters
 - BOD has not dropped enough to omit the Trickling Filters or even half of them.
 - The cost for additional Aeration Basins that could replace the Trickling Filters is too high compared to Biofilters
- Regarding Phosphorus
 - Chemical addition using Ferric Chloride is being installed at the WRF because:
 - BNR is decisively more expensive than chemical addition and,
 - Phosphorus limits aren't below the practical range for chemical addition.

Dayton is advancing their Implementation Plan



Thank you.

Nick Dailey, P.E.



Senior Engineer II
Department of Water
Division of Water Reclamation | City of Dayton
Office 937.333.1839
nick.dailey@daytonohio.gov

Sharon Vaughn



Plant Operations Supervisor
Department of Water
Division of Water Reclamation | City of Dayton
Office 937.333.1872
sharon.vaughn@daytonohio.gov




Peter Kube, P.E.
peter.kube@arcadis.com
513-985-8039



Additional Items to Share


Energy Efficiency Recommendations

Top 5 Energy Use Systems



Major Process/Top Energy Use Systems	Electric Energy Use (%)
#1 INTERNAL PLANT PUMPING	26.68%
#2 SECONDARY TREATMENT	22.73%
#3 INFLUENT PUMPING	16.84%
#4 SLUDGE HANDLING	6.78%
#5 ANAEROBIC DIGESTION	6.43%
Balance of Plant Identified	13.28%
Balance of Plant Unidentified	7.25%
Total	100.00%

GIS created





Thank you.

Nick Dailey, P.E.



Senior Engineer II
Department of Water
Division of Water Reclamation | City of Dayton
Office 937.333.1839
nick.dailey@daytonohio.gov

Sharon Vaughn



Plant Operations Supervisor
Department of Water
Division of Water Reclamation | City of Dayton
Office 937.333.1872
sharon.vaughn@daytonohio.gov



Peter Kube, P.E.
peter.kube@arcadis.com
513-985-8039