

30 May 2019


# Lower Scioto WRF Treatability Study

Jim Fitzpatrick  
Principal Process Engineer



**BLACK & VEATCH**

# Agenda



# Background and Purpose

# General Objectives

- Develop treatment process model for LSWRF
- Preliminary evaluation of process performance of existing facilities and operations compared to alternatives to **optimize performance** at current flows and loads and anticipated flows and loads for the future.

**Supplemental facility planning for the future of LSWRF**

PARAMETER	UNITS	FINAL EFFLUENT LIMITATIONS <sup>A</sup>	
		MONTHLY AVERAGE	WEEKLY AVERAGE
CBOD <sub>5</sub>	mg/L	3.0	5.0
	kg/day <sup>B</sup>	15.9	26.5
Nitrogen, Total	mg/L	-	10
	kg/day <sup>B</sup>	-	53.0

**Notes:**

A. Maximum allowable at Final Outfall 001 unless otherwise noted

B. Based on average design flow of 1.4 mgd

# OEPA Compliance Report


## Part I, C - Schedule of Compliance

### 1. Compliance Report

The permittee shall as soon as possible but no later than 24 months after the effective date of the permit meet final limits for CBOD and total nitrogen at outfall 4PK00004001. The permittee shall also submit the following:

- The permittee shall submit a report on the treatment plant effectiveness at meeting final effluent limits for CBOD and total nitrogen during the first 12 Months of the permit. {Event Code 34099}
- Within 24 Months of the permit's effective date, the permittee shall meet the final effluent limitations. {Event Code 20099}

# Phased Approach





# Existing Facilities

## Preliminary Treatment

- 2 Drum Screens (1/4")
- 1 Manual Bar Screen (1")

## High-Pressure Air

Air Receiver + 2 Screw Compressors




## Low-Pressure Air

4 Multi-Stage Centrifugal Blowers



## 2 Aeration Basins



## 2 Clarifiers



## RAS/WAS Pump Station

## Biosolids Processing

### 2 Aerobic Digester Tanks

3 Blowers

1 Centrifuge




## 3 Tertiary Filters



## UV Disinfection



- **Optional flow paths to help address:**
  - **low loads (--- MLSS Outlet)**
  - **wet-weather (--- Step-Feed)**
  - **nitrification/denitrification conditions (--- MLSS Feed)**







# Observations, Results and Conclusions

# Influent Flow Rate



## Historical



## Future Projections





# Influent TSS



Relatively low-strength wastewater



# Influent CBOD<sub>5</sub>



Carbonaceous oxygen demand 16 to 50x less than basis of design for existing fine-bubble diffusers.



# Influent NH<sub>3</sub>-N



Nitrogenous oxygen demand 5 to 25x less than basis of design for existing fine-bubble diffusers.


- **1/3 of existing basin in service**
- **Timers used to cycle DO in the OX zone**
  - **60 min on, 150 min off**

The diagram illustrates the flow paths for the Aeration/Clarifier Flow Splitter. Key components and flow paths include:


- INF (Influent):** Represented by a blue arrow at the top left, entering the system.
- MLSS In (Mixed Liquor Suspended Solids In):** Represented by a yellow arrow, showing the return of sludge to the aeration tank.
- RAS (Return Activated Sludge):** Represented by a brown arrow, showing the return of sludge from the clarifier to the aeration tank.
- Clarifier:** A large circular tank where sludge is settled. The bottom section is shaded green and labeled "Cycled Aeration to Swing AX/OX".
- EFF (Effluent):** Represented by a blue arrow at the bottom, showing the exit of treated water.
- MLSS Out:** Represented by a green arrow, showing the exit of sludge from the clarifier.

The diagram also shows various pipes, valves, and equipment, including the "Aeration Tank No. 1", "Flow Splitter", and "Clarifier".

# Effluent TSS Trend




# Effluent CBOD<sub>5</sub> Trend







# Effluent $\text{NH}_3\text{-N}$ Trend




# Effluent TN Trend



# Effluent TP Trend



# Process Model to Evaluate Performance and Alternatives for Future Conditions





# Model Calibration and Scenarios


## Calibration

- B&V/GPS-X default fractionation for C, N and P species. Soluble:particulate, biodegradable:total, etc.
- B&V/GPS-X default kinetic parameters
- Calibration month: April 2018. Cyclic aeration (60 min ON / 150 min OFF).


Flow/Load Condition	Process Configuration		
	Existing	Modified Ludzack Ettinger (MLE)	Anoxic Step-Feed
Current	0.1 mgd	0.1 mgd	0.1 mgd
50% Design	0.7 mgd	0.7 mgd	0.7 mgd
100% Design	1.4 mgd	1.4 mgd	1.4 mgd

# Existing Configuration

- One train in service
- 1/3 anoxic (AX), 2/3 oxic (OX)
- Continuous mixing / aeration
- Step-feed options




- One train in service
- 1/3 anoxic (AX), 2/3 oxic (OX)
- Continuous mixing / aeration
- 3Q mixed liquor recycle pump
- No step feed



# Anoxic Step-Feed Alternative

- One train in service
- 1/3 anoxic (AX), 2/3 oxic (OX)
- Continuous mixing / aeration
- **AX zones at step-feed locations**
- **No MLR pumping**





# Summary of Model Results

Parameter	Existing	MLE	AX Step-Feed				
Flow, mgd *	1.4	1.4	1.4	1.4	0.7	0.25	0.1
MLSS, mg/L	1450	1450	1450	1600	900	600	650
SRT <sub>a</sub> , days (20°C)	9	9	9	9	10	20	48
Clarifier SLR, ppd/sf	10.2	10.2	10.2	11.4	3.2	0.8	0.4
Clarifier SOR, gpd/sf	420	420	420	430	217	82	37
WAS, lb/day	475	470	475	530	287	105	49
Effluent							
TSS, mg/L	1.8	1.8	1.8	1.8	0.9	0.4	0.2
CBOD <sub>5</sub> , mg/L	1.6	2.0	1.9	1.9	1.6	1.3	1.2
NH <sub>3</sub> -N, mg/L	0.07	0.10	0.15	0.15	0.15	0.1	0.1
TN, mg/L	13.4	10.0	9.0	9.1	8.6	7.4	6.2
	No biosolids dewatering returns			Biosolids dewatering centrate including 150,000 gal/wk imported WAS from package plants			
* COD = 144 mg/L, BOD/COD=0.45, CBOD/BOD=0.85, TKN=24 mg/L, NH <sub>3</sub> -N = 18 mg/L							

# Air Flow Estimates for Low-Pressure, Fine-Bubble Diffusers

Design Load Condition	Projected Year	Air Demand, scfm		
		Biological Process		Mixing
		Minimum	Maximum	*
0.1-mgd AADF	Now	24	29	298
0.31-mgd AADF	2024	78	88	298
1.4-mgd AADF	>2047	346	463	298
* Based on 5 scfm/kcf				



# Existing Aeration System

Low-Pressure Air (11 psig)	High-Pressure Air (60 psig)
For process dissolved oxygen and mixing	For mixing only
Multi-Stage Centrifugal Blowers	Screw Compressors
2 x 1,100 scfm	2 x 188 scfm @ 115 psig
2 x 2,200 scfm	Air Receiver (1)
Fine-Bubble Diffusers	Air Valve Panels (4 per basin)
FlexAir™ MiniPanel™	Large-Bubble Mixing Plates
216 per basin	Pulsair™
	36 per basin

- Inadequate turndown for process air at extremely low startup loads
- Blower system not designed for frequent on/off operation

# Conclusions and Recommendations

# Treatability Study Conclusions and Recommendations

## Short Term

- Extremely lower influent loading than original design
- Turndown constraints of existing aeration and RAS systems limit operational options and energy efficiency
- Cyclic aeration can comply with permit, but at higher O&M cost than utility standards
- Current 1/3 basin operation can treat up to about 0.31-mgd AADF, which is projected to occur in about five years (2024).

## Long Term

- 1.4-mgd AADF is projected to occur 27 to 60 years from now.
- Proceed with preliminary-level design of anoxic step-feed process retrofits to improve performance and O&M costs:
  - Anoxic zone baffle alternatives
  - High-pressure air mixing modifications
  - Low-pressure diffused air modifications, including smaller blowers
  - RAS pumping alternatives
  - Basis of Design Memorandum



O'Shaughnessy Dam and Bridge  
Scioto River, Ohio



From maps.roadtrippers.com



SEOWEA



THANK YOU!!

**Jim Fitzpatrick**

Principal Process Engineer

+1 913-458-3695

[FitzpatrickJD@bv.com](mailto:FitzpatrickJD@bv.com)

**Sierra McCreary**

Project Manager

+1 614-454-4394

[McCrearySB@bv.com](mailto:McCrearySB@bv.com)

**Jonathan Leonard**

Project Engineer

+1 614-454-4393

[LeonardJ@bv.com](mailto:LeonardJ@bv.com)



# Bullpen

# Existing Facilities

## 2 Aeration Basins

### 3 Anoxic Zones

- Mixing Plates (High-Pressure Air)
- Fine-Bubble Diffusers (Low-Pressure Air)

### 2 Oxic Zones

- Fine-Bubble Diffusers (Low-Pressure Air)
- 1 Mixing Zone (High-Pressure Air)

## 2 Clarifiers

- 65-ft Diameter
- Center Feed
- Flocculator Feedwell
- Spiral Scraper
- Ducking Skimmers
- Interior Launderers (Covered)

## Preliminary Treatment

- 2 Drum Screens (1/4")
- 1 Manual Bar Screen (1")

## Low-Pressure Air (11.1 psig)

### Multi-Stage Centrifugal Blowers

- 2 @ 1100 scfm
- 2 @ 2200 scfm

## High-Pressure Air (60 psig)

### Air Receiver

### Screw Compressors

- 2 x 188 scfm @ 115 psig


## RAS/WAS Pump Station

3 x 650 gpm @ 35 ft TDH

## Biosolids Processing

### 2 Aerobic Digester Tanks

- 65-ft dia x 15-ft SWD
  - Coarse-bubble diffusers
  - 3 Heliflow PD Blowers (1500 scfm @ 8.3 psig)
- Dewatering Centrifuge**



## Tertiary Treatment

### 3 Traveling Bridge Filters

- Anthracite/Sand

## Effluent Disinfection

UV Vertical LPHO