

City of Columbus

Often Overlooked - Lessons from WWTP Non-Potable Water Model

Darin Wise, Columbus SWWTP

Dante Fiorino, Brown and Caldwell

June 26, 2019

THE CITY OF
COLUMBUS
ANDREW J. GINTHER, MAYOR

DEPARTMENT OF
PUBLIC UTILITIES




Non-Potable Water

- Treated effluent water
- Pumped from Effluent Pump Station
- Used for process demands
- Used for flushing lines and tanks
- Used for sampling, other misc.
- NOT used for drinking



Don't drink the water!!!


Agenda



Existing System

Darin Wise, Southerly WWTP

Existing System




Effluent Pump Station

- 4 vertical turbine pumps with 3,250 gpm capacity, 250 hp motor
- Firm capacity of 9,750 gpm (3 in service + 1 redundant)
- Operated at a pressure of 84 psi
- Controlled by a local control panel and driven by an adjustable frequency drive (AFD)
- Minimum speed of 80%




SWWTP Non-Potable Pump


Existing Demand




Major Process Demands



SCADA Monitored Locations



Existing Demand Distribution




Evaluation Goals

Darin Wise, Southerly WWTP

Purpose

- Planned CEPT projects will:
 - Increase demand on existing processes
 - Add new demands
 - Add new mains and hydrants
- A calibrated hydraulic model can:
 - ✓ Analyze existing system
 - ✓ Assess ability to meet future demands
 - ✓ Address existing concerns

Southerly in Transition



Pump Station Capacity




System Pressure

- Controlled by 84 psi pressure set point
- Based on abandoned incinerator requirements
- Evaluate lowering set point for current demands
- Would save energy and pump maintenance




Non-Potable Pressure Gauge




SWWTP NPW SCADA Screen

Pump Cycling

- Pumps frequently cycle on and off
- Operating at low speed on the AFD controlled range
- Undesirable timers built into 'Pump Director'
- Causes poor operability and increased maintenance



Grit Tank Demand Variation



NPW Pump Curve

Future Planning Impacts


- CEPT / BLAF connections
- New Gravity Thickener Tank
- Sodium Bisulfite Carrier Water
- Digester Process Water

Model Development

Dante Fiorino, Brown and Caldwell

Model Development

- InfoWater hydraulic modeling platform
- GIS water network from CAD drawings
- Process demands where they connect to system



Field Testing


Goal: obtain field data on current system operations for calibration

- Typical system operation
 - 8 pressure sensors (4 temp)
 - 5 flow meters (4 temp)
 - 1 week period
- Hydraulic stress test
 - High flow scenario
 - Use yard hydrants
- Pump curve testing




NPW Pump Check Valve

Monitoring Locations



Hydraulic Stress Test



Model Calibration

- Steady-state calibration
 - Adjust assumed C-factors
 - Match pressure observed losses
- Extended period simulation
 - Evaluate pressure and flow trends
 - Identify peak conditions
- Within 2 psi at all monitored locations



Non-Potable Water Strainer

Test Results

| Test | Location | Pre Flow (gpm) | Test Flow (gpm) | Demand (gpm) |
|---------|---------------------|----------------|-----------------|--------------|
| Test #1 | Grit Tanks | 1,775 | 4,300 | 2,525 |
| Test #2 | East Primary | 1,525 | 3,050 | 1,525 |
| Test #3 | Thickening Facility | 1,350 | 5,025 | 3,675 |
| Test #4 | Gravity Thickener | 2,000 | 7,050 | 4,800 |

| Test | Critical PM | P Drop (psi) | Actual P (psi) | Model P (psi) |
|---------|-------------|--------------|----------------|---------------|
| Test #1 | PM6 – RSP | 28.2 | 64.3 | 64.3 |
| Test #2 | PM7 – EPC | 9.3 | 82.1 | 81.9 |
| Test #3 | PM3 – CPC | 10 | 86.8 | 88.5 |
| Test #4 | PM2 – SCB | 13.2 | 79.3 | 81.1 |

Model Analysis


Once the model is calibrated it was used to review capacity and performance

- System deficiencies in available pressure or flow
- Capacity to support future process demands
- Evaluation of operational or physical changes to mitigate deficiencies



Non-Potable Water Header


Model Determinations




Findings

Dante Fiorino, Brown and Caldwell


Existing Pump Station Capacity




Existing System Pressure



Existing Pump Cycling



Future BLAF / CEPT



Gravity Thickener Dilution

Operating Pressures

- Existing = 90+ psi
- Required = 30 psi

Problems

- Wasted energy
- Demand increasing
- Difficult Q control

Solution


- P reducing valve
- Increased control



Sodium Bisulfite Carrier Water


Feeder main undersized, unmetered, largest existing demand

- Valve open in warm weather
- Valve closed in cold weather
- CEPT project to modify feed
- Add SCADA controlled valve
- Increase main from 2-inch to 4-inch



Sodium Bisulfite Carrier Water

Digester Process Water



Non-Potable Water

- Typically least important process for any given project
- Part of every process at SWWTP
- Individual impact is small
- Overall impact is large
- SWWTP took a holistic look
- Improved existing performance
- Better prepared for future demands
- Don't drink the water!



Don't drink the water!!!

Acknowledgements

- City of Columbus
 - Stacia Eckenwiler
 - Troy Branson
 - Rick Kent
 - Jeff Hall
 - Jeff Bartoe
- Brown and Caldwell
 - Dave Nitz
 - Christie Patel

Presenters

- Darin Wise
 - Columbus Southerly WWTP
 - Plant Manager
 - (614) 645-3248

- Dante Fiorino
 - Brown and Caldwell
 - Sr. Engineer
 - (614) 923-5009

Questions/Discussion

