Improvements for Nutrient Removal at a Package Plant

Package Plant Nutrient Management



The Teams

- Regional Sewer District
 - Collections
 - Engineers
 - Maintenance/Electronic Maintenance
 - Operations
- Consulting Engineers



What

- ► TIN and TN limits
- Current Improvements
- Nutrient Profiling
- Future Improvements
 - Package Plant Upgrades
 - Studies
- CIP vs In-House
 - ► Fine-bubble diffusers
 - Mixers

Where

- Package Plants
 - ► Tartan Fields
 - Scioto Reserve
 - ► Lower Scioto





When and Why

- Implementation of the LAMP permits
- Regulatory-driven

Page 3 4MP00008*CM

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

 During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from outfall 4MP00008601. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 601 - Final

Effluent Characteristic	Discharge Limitations							Monitoring Requirements		
	Concentration Specified U			Jnits Loading* kg/day			day	Measuring	Sampling	Monitoring
Parameter	Maximum Minimum		Weekly Monthly		Daily Weekly		Monthly	Frequency	Туре	Months
00400 - pH - S.U.	9.0	6.0		-			-	1/Month	Grab	All
00530 - Total Suspended Solids - mg/l		-		45		-	-	1/Week	Composite	All
00552 - Oil and Grease, Hexane Extr Method - mg/l	10	2	(2)	20	-	-	-	1/Quarter	Grab	Quarterly
00640 - Nitrogen, Inorganic, Total - mg/l	-	2		10		-	-	1/Week	Composite	All
00951 - Fluoride, Total (F) - mg/l	1.0	-	-	-	-	-	-	1/Year	Grab	Yearly
01002 - Arsenic, Total (As) - ug/l	100	-	0.5	7.5			-	1/Year	Grab	Yearly
01012 - Beryllium, Total - ug/l	100	5.0	10.7	-		•	-	1/Year	Grab	Yearly
01022 - Boron, Total - ug/l	750			•2	-	-	S	1/Year	Grab	Yearly
01037 - Cobalt, Total (Co) - ug/l	50	-		-	-	-	-	1/Year	Grab	Yearly
01045 - Iron, Total (Fe) - ug/l	5000	-	1.4	-		-	-	1/Year	Grab	Yearly

Where We Left Off

► Hydraulic Improvements to Tartan



Hydraulics First, Biology Next




TF Drawbacks

- ► No EQ
- Sludge Holding Tank
 - Storage Space
 - Decanting
- RAS control
- New Neighbors/odor control



How SR differs

- Aeration in hand
- Parallel tanks/two plants
- Less corrosion



Modeling

- **OECC**
- Lower Scioto
- ► Tartan Fields
- Northstar



Nutrient Reduction is for Everyone!

- Nitrification/Denitrification
- Make an anoxic zone in your aeration tank
 - Blower Timers
 - Sampling
 - Settlometer



Settlometer vs Centrifuge





Nitrification

- Oxygen
- Time
- Temperature
- MLSS
- Alkalinity






Denitrification

- Nitrate
- Time
- Temperature
- MLSS
- Alkalinity



IMLR

- Nitrate Recycle
- Not RAS
- To feed or not to feed (Carbon)



IMLR at Tartan



Mixing

- Course Bubble
- ► Floating Surface




Mini Mixing Study


- Course bubble mixing
- Lower Scioto vs Northstar
- DO profiling



Northstar Mixing Study



Lower Scioto Mixing Study



Nitrite Shunt

- Nitrification/Denitrification Shortcut
- Simultaneous nitrification/denitrification
- Ammonium to Nitrite to Nitrogen Gas
- Nitrite oxidizing bacteria repressed
 - Low DO?

Nitrite Lock

- ► Typical Effluent Nitrite is less than 1 mg/L
- Nitrite interferes with Cl₂ residual
 - ▶ 1 mg/L of Nitrite consumes 2 mg/L of Cl₂ residual
- Short aeration detention time
- Ammonia oxidizing bacteria
 - Nitrite oxidizing bacteria?

Current Process Control

- Ammonia results in 18 minutes
- Nitrate results in 5 minutes
- Anoxic Zones
- Aeration Zones
- Nutrient Probes for Real-time results



Monthly Nutrient Profiling

- Ammonia
- Nitrate
- Orthophosphate



Nutrient Profiling

- ► Influent
- Digester Decent
- ► Anoxic Tank
- **RAS**
- ► Aeration Tank
- ▶ Clarifier
- ► Effluent




Influent

- CBOD
- Ammonia
- Nitrate
- ► Total Phosphorus



Decent Numbers

	Amn	nonia	Niti	rate	Ortho-Phosphate		
	Influent	Effluent	Influent	Effluent	Influent	Effluent	
Lower							
Scioto	15.7	0.3	7.0	4.4	6.6	1.0	
Tartan							
Fields	35.3	0.8	1.1	4.9	14.3	3.0	
Scioto							
Reserve	38.8	2.2	0.8	3.1	15.1	7.8	
Northstar	37.8	1.3	1.1	6.0	12.9	9.5	



—Ammonia —Nitrate

Lower Scioto Treatability




Package Plant Upgrades


- ► Tartan Fields
- Scioto Reserve
- Lower Scioto


Other Package Plants

- ► Future NPDES discharge for Northstar
- Ammonia Limits for three smaller package plants


You Nutrient Team








Lower Scioto Nitrate Spike



Ortho-Phosphate at TF



Future Projects

- High Ammonia at Scioto Reserve
- Low Ammonia at Lower Scioto
- IMLR pump at Tartan Fields
- Nutrient Modeling At Northstar
- Blowers at Lower Scioto
 - Constant air vs cyclic aeration

Key Take Away

"You really have to do the lab work, and you have to do the documentation, so you know that when a change is made, this is what you got. And then look at trends to know what happened over a period of time."

-Tim Pfeifer, Slinger (WI) WRF

Thank You!

To all the operators and engineers contributing to these projects!



Questions

FEATURED NEWS





Cease the Grease
Posted Monday, June 4, 2018




Keep Wipes out of Pipes

Posted Monday, June 4, 2018



Bug's Menu



Dissolved Oxygen



Nitrate



Sulfate

